



JAMAICA

**Electric Utility
Sector**

**Generation
Code**

[July 2013]

DOCUMENT TITLE AND APPROVAL PAGE

DOCUMENT NUMBER: 2013/003/ELE/TEC/001

1. DOCUMENT TITLE: Electric Utility Sector Generation Code, July 2013

2. PURPOSE OF DOCUMENT

This document covers the guiding principles, operating procedures and Technical Standards governing operation of the Jamaican Electric Power Grid and all interconnected Generating Facilities. The Code seeks to facilitate the economic, safe and reliable operation of the Jamaican Power Grid and to avoid any undue discrimination among Generators. The provisions of the Code are enforceable under the Office of Utilities Regulation (OUR) Act 1995 (as amended) as well as the Amended and Restated All-Island Electric Licence 2011 and any other applicable enactment.

3. RECORD OF DOCUMENT ON ISSUE

Document Number	Description	Date
	Electric Utility Sector Generation Code	November 1997

4. APPROVAL

This document is approved by the Office of Utilities Regulation and the provisions therein become effective **August 1, 2013**.

On behalf of the Office:



.....
Maurice Charvis
Director General

July 29, 2013

TABLE OF CONTENTS

LIST OF REVISIONS	ii
PREFACE.....	vii
INTERPRETATION OF CODE.....	ix
1 CONNECTION CONDITIONS.....	1
1.1 METHOD OF CONNECTION.....	1
1.1.1 INTERCONNECTION POINT	2
1.1.2 SUPPLY VOLTAGE.....	2
1.1.3 CONFIGURATION OF GENERATION SUBSTATIONS.....	2
1.2 GENERATOR PERFORMANCE STANDARDS AND TECHNICAL.....	3
CRITERIA	3
1.2.1 TECHNICAL STANDARDS.....	3
1.2.2 PERFORMANCE STANDARDS	3
1.2.3 STATION CAPABILITIES.....	4
1.2.4 PROTECTION REQUIREMENTS.....	6
1.3 GRID OPERATOR PERFORMANCE AND TECHNICAL STANDARDS	7
1.4 OTHER RIGHTS VESTED WITH THE GRID OPERATOR.....	8
1.4.1 INSPECTION OF GENERATING PLANT BY GRID OPERATOR.....	8
1.4.2 DISCONNECTION OF GENERATOR BY THE GRID OPERATOR.....	9
2 OPERATIONAL METERING.....	10
2.1 TECHNICAL STANDARDS FOR OPERATIONAL METERING.....	10
2.1.1 LOCATION OF METERING EQUIPMENT	10
2.1.2 METERING STANDARDS	10
2.1.3 SEALING, FIELD TESTING AND INSPECTION OF METERING SYSTEMS	11
2.2 METER READING PROCEDURES	12
2.2.1 PARAMETERS FOR METER READING.....	12
2.2.2 FREQUENCY OF READING	12
2.2.3 CONTROL PROCEDURES.....	13
2.2.4 METERING REQUIREMENTS FOR GENERATORS <100KW	13
2.3 RECONCILIATION PROCEDURES	13

2.4	RESOLUTION OF DISPUTES OVER RECORDED METERING DATA.....	14
3	GENERATOR SCHEDULING AND DISPATCH	15
3.1	CRITERIA FOR SCHEDULING AND DISPATCH.....	15
3.2	MERIT ORDER SCHEDULING	15
3.2.1	REVIEW OF MERIT ORDER AND DISPATCH INPUT	16
3.3	NOTIFICATION OF MERIT ORDER.....	18
3.4	SYSTEM SECURITY STANDARDS	18
3.4.1	SPINNING RESERVE	18
3.4.2	OPERATING RESERVE	18
3.5	UNIT COMMITMENT SCHEDULING AND SYSTEM OPERATION.....	19
3.5.1	PREPARATION OF UNIT COMMITMENT SCHEDULE.....	19
3.6	DISPATCH INSTRUCTIONS	21
3.6.1	INSTRUCTION TO SYNCHRONIZE / DESYNCHRONIZE.....	22
3.6.2	FREQUENCY AND VOLTAGE CONTROL	22
3.6.3	CHANGES TO GENERATION CONDITIONS	23
3.7	SWITCHING INSTRUCTIONS.....	24
3.8	NON CENTRALLY DISPATCHED PLANT.....	25
3.9	COMMUNICATION AND REPORTING.....	25
3.9.1	DESIGNATED CONTACT PERSONS.....	25
3.9.2	SYSTEM CONTROL CENTER RECORD OF DISPATCH	25
3.9.3	GENERATOR OPERATIONS LOG	27
3.10	FUEL SUPPLY AGREEMENT.....	28
3.11	GENERATOR SCHEDULING & DISPATCHING TOOLS	29
3.12	TRANSPARENCY AND FAIRNESS.....	29
3.13	NEW TECHNOLOGIES.....	30
4	LOAD SHEDDING AND POWER RESTORATION	31
4.1	LOAD SHEDDING PROCEDURES	31
4.1.1	UNDER FREQUENCY (AUTOMATIC) LOAD SHEDDING.....	31
4.1.2	MANUAL LOAD SHEDDING	32
4.2	CONTINGENCY PLANS FOR POWER RESTORATION.....	33

4.2.1	PROCEDURES FOR RESTORATION OF POWER FOLLOWING	33
	WIDESPREAD BLACKOUT	33
5	GENERATOR MAINTENANCE PLANNING	35
5.1	LONG TERM MAINTENANCE	35
5.1.1	PLANNING HORIZON	35
5.1.2	ANNUAL COMMITMENT OF MAINTENANCE PROGRAM	35
5.1.3	CHANGES TO THE COMMITTED MAINTENANCE SCHEDULES	36
5.2	SHORT TERM OUTAGE PROGRAM	37
6	TESTING AND MONITORING	38
6.1	PROCEDURES FOR CONDUCTING TESTS	38
6.2	STANDARD TESTS	38
6.2.1	TEST PRIOR TO FIRST SYNCHRONIZATION	38
6.2.2	TESTS AFTER FIRST SYNCHRONIZATION	39
6.3	CO-GENERATORS AND NON-DISPATCHABLE GENERATORS	42
6.4	TESTING OF METERING SYSTEM	42
6.5	PARAMETERS MONITORING	42
7	GENERAL PROVISIONS	43
7.1	MATTERS TO BE AGREED	43
7.1.1	OUR RULINGS AND DIRECTIONS	43
7.1.2	OTHER AGREEMENTS	43
7.1.3	TREATMENT OF THIRD PARTY CONTRACTS	43
7.2	MONITORING AND REVIEW OF THE GENERATION CODE	44
7.2.1	THE ROLE OF THE OUR	44
7.2.2	THE GENERATION CODE REVIEW PANEL	44
7.2.3	REVISIONS OF THE CODE	46
7.3	UNFORESEEN CIRCUMSTANCES AND SYSTEM EMERGENCIES	47
7.3.1	UNFORESEEN CIRCUMSTANCES	47
7.3.2	FORCE MAJEURE	47
7.4	NON-COMPLIANCE	47
7.5	DEROGATION	48

7.5.1	NORMAL PROCEDURE WHEN NON-COMPLIANCE IS	48
7.5.2	DEROGATION FOR EXISTING APPARATUS NOT IN COMPLIANCE	49
7.6	DISPUTE RESOLUTION	49
7.6.1	MUTUAL DISCUSSION.....	49
7.6.2	REFERRAL AND DETERMINATION BY THE OUR.....	49
7.7	NOTICES	51
	SCHEDULE A: TERMS AND DEFINITIONS.....	53
	SCHEDULE B: REQUIRED COMMUNICATION EQUIPMENT.....	60
	SCHEDULE C: LOAD SHEDDING SCHEME	62
	SCHEDULE D: RESERVE MARGIN POLICY	63
	SCHEDULE E: EXISTING GENERATING SYSTEM	64
	SCHEDULE F: GRID OPERATOR INTERCONNECTION CRITERIA	66

PREFACE

The Generation Code (hereinafter called the "Code") covers the guiding principles, operating procedures and Technical Standards governing operation of the Jamaican Electric Power System Grid and all interconnected Generating Facilities. The Code seeks to facilitate the economic, safe and reliable operation of the Jamaican Power System and to avoid any undue discrimination among Generators. The provisions of the Code are enforceable under the Office of Utilities Regulation Act 1995 (as amended), the Amended and Restated All Island Electric Licence 2011 and any other applicable enactment.

The Code is divided into the following sections:

Connection Conditions specifies the normal method of connection and the minimum technical, design and operational criteria which must be complied with by all Generators and prospective Generators.

Operational Metering specifies the Technical Standards and procedures for metering applicable to Metering Systems installed by Generators.

Generation Scheduling and Dispatch specifies the procedures for Generating Unit scheduling, dispatch, System security and communications between Generators and The Grid Operator via the System Control Center.

Load Shedding and Power Restoration specifies the procedures for automatic and manual shedding of load and restoration of power following partial or total black out.

Generator Maintenance Planning specifies the criteria and procedures governing the planning and scheduling of maintenance requirements of Generators' Generating Facilities.

Testing and Monitoring specifies the list, time table and procedures for all tests to be performed by the Generator and Grid Operator.

General Provisions encompass several provisions pertinent to the functioning of the Code, including procedures for review of the Code and for derogation of existing installations and equipment not in compliance with the standards specified in this Code at the time of execution.

Jamaica Public Service Company Limited ("JPS") has responsibilities under this Code in two distinct capacities. These are as follows:

- i) JPS is responsible for prudent and efficient management of the Jamaican Electric Power System and, in that capacity, for dealing with all Generators in a consistent and non-discriminatory manner. This Code applies the term "Grid Operator" whenever referring to JPS in this capacity;

- ii) As the owner of power stations, JPS is also subject to the rights and obligations in this Code as apply to Independent Power Producers (“IPPs”) and Co-generation Facilities. Any reference to "Generators" in this Code should be interpreted to include JPS in this capacity.

INTERPRETATION OF CODE

In this code:

- i) Expressions defined under **‘Terms and Definitions’** (Schedule A) shall bear the respective meaning set out therein;
- ii) The headings are for convenience only and shall not be used in construing the Code;
- iii) The singular includes the plural and vice versa;
- iv) Terms not herein defined shall have the meaning ascribed thereto in the Oxford English Dictionary, such meaning as ascribed under the relevant statute and regulations as well as such meaning as normally ascribed and accepted within the power industry ; and
- v) References to clauses, recitals and schedules are, unless the contents otherwise requires, references to clauses of and recitals and schedules to this Code.

1 CONNECTION CONDITIONS

Connection Conditions specifies the normal method of connection and the minimum technical, design and operational criteria which must be complied with by any Generator and prospective Generators.

Additionally, details specific to each Generator's connection may be set out in a separate Connection Agreement or in some cases, the relevant Power Purchase Agreement. The Connection Conditions set out in the Code shall be read in conjunction with either or both of these Agreements as relevant. In the event that, there is any conflict between the provisions of the Code and any Connection Agreement and/or Power Purchase Agreement and the said Connection Agreement and/or Power Purchase Agreement was signed before the present Code came into effect, then, the provisions of the Connection Agreement and/or Power Purchase Agreement will supersede the Code. Notwithstanding the foregoing, all Connection Agreements and/or Power Purchase Agreements shall be read in conjunction with the Code in force at any material time and in accordance with Sub-section 7.1 of this Code.

1.1 METHOD OF CONNECTION

The method of connection shall be determined on the basis of several technical and economic factors which include:

- i) Proximity to System Grid;
- ii) Generating Unit (MW) rating or Generating Facility (MW) capacity;
- iii) Supply voltage;
- iv) Reliability considerations;
- v) Auxiliary power supply;
- vi) Substation configuration;
- vii) Protection systems/devices; and
- viii) Costs

It will not be technically or economically practicable to achieve uniformity of the method of connection. In all cases however, Prudent Utility Practice will influence the method adopted.

The method chosen by the Generator shall be reviewed and approved by the Grid Operator on the grounds of System security, stability and safety.

1.1.1 INTERCONNECTION POINT

The Generating Unit(s) shall be interconnected to the System Grid via a Substation. The Interconnection Point shall normally be on the High Voltage side (System Grid side) of the generator step-up transformer and will demarcate the boundary of responsibility between the Generator and the Grid Operator.

Generators, with capacity of 60 MW or more shall be interconnected to the switchyard/substation to satisfy the N-1 security criteria. This implies that the loss of any single Transmission element connecting a Generator to the Transmission System shall not result in a loss of generating capacity greater than 60 MW.

The finalized number of connection points shall be determined by a system analysis study at the time of interconnection to the system.

The Generator shall be responsible for all costs related to interconnection to the Grid.

1.1.2 SUPPLY VOLTAGE

The voltage level at which the Generating Unit(s) are connected to the System Grid will be dependent on but not limited to the size and number of units and the other factors that determine the Interconnection Point.

Subject to other technical considerations, Generating Units with a Rated Capacity of 10 MW or above shall be connected to the Transmission System at 69 kV or 138 kV.

Generating Units with a Rated Capacity of below 10 MW may be connected to either the Transmission System at 69 kV or 138 kV or the primary Distribution System at 24 kV or less.

Embedded Generating Facilities with Rated Capacity between 1MW and 10MW may be interconnected via a dedicated feeder recloser from the Substation to the Facility.

1.1.3 CONFIGURATION OF GENERATION SUBSTATIONS

All Generation Substations shall have the capability to disconnect or separate, from the System Grid, any transmission line and Generating Unit which is interconnected to the Substation.

For reasons of ensuring safety and reliability of operation, Generation Substations with more than three transmission lines and Generating Units interconnected to them shall be of a **‘breaker and a half’** configuration. The size of the Generating Units shall be considered for applicability of the breaker and a half requirement. The Substation shall be

equipped with all requisite protection measures necessary to meet the Grid Operator's System protection standards as set out in Clause 1.2.4.

1.2 GENERATOR PERFORMANCE STANDARDS AND TECHNICAL CRITERIA

1.2.1 TECHNICAL STANDARDS

All components of the connection shall be constructed, installed and tested in accordance with the current edition at the time of construction of the following codes and standards, or their international equivalents and Prudent Utility Practice:

ACI	American Concrete Institute
ANSI	American National Standards Institute
ASCE	American Society for Civil Engineers
ASME	American Society for Mechanical Engineers
ASNT	American Society for Non-Destructive Testing
ASTM	American Society for Testing Materials
AWS	American Welding Society
UL	Underwriters Laboratory
IEC	International Electrotechnical Commission
IEEE	Institute of Electrical and Electronic Engineers
ISO	International Organization for Standardization
NBC	National Building Code (Jamaica)
NIST	National Institute of Standards and Technology
NEC	National Electric Code
NEMA	National Electric Manufacturers Association
NESC	National Electric Safety Code
NETA	National Electric Testing Association
NFPA	National Fire Protection Association
SSPC	Steel Structures Painting Council
BSJ	Bureau of Standards Jamaica
NEPA	National Environmental Planning Agency (Jamaica)
OSHA	Occupational Safety and Health Administration

1.2.2 PERFORMANCE STANDARDS

Each Generating Unit interconnected to the System Grid shall be required, as a minimum, to meet the following performance standards:

- i) Sustained operation at any Load within the loading limits within the System frequency range of 49.5 Hz to 50.5 Hz;
- ii) Emergency operation within the Generator loading limits and within the system frequency range of 48.0 Hz to 52.5 Hz;
- iii) Maintain normal rated output at the System Grid normal voltages specified in Sub-section 1.3;
- iv) Sustained operation at the rated Power Factor set out in the relevant and appropriate Interconnection Agreement; and
- v) Grid Interconnection Criteria (Appendix G)

1.2.3 STATION CAPABILITIES

i) Synchronizing Facilities

Each Generating Unit shall be equipped with synchronizing facilities to ensure Synchronization with the System Grid. Two independent synchronizing facilities, preferably one automatic and one manual shall be provided, however, the primary must be automatic. The Synchronization facilities shall include a synchronism check relay to support synchronization under the following range of conditions:

- a) System Grid frequency within the limits 48.0 to 52.5 Hz; and
- b) System Grid voltages within the limits specified in Sub-section 1.3.

ii) Auxiliary Supply

Each Generating Unit shall have the facility to provide its auxiliary supply during normal operation. Each Generator shall provide the facility to connect to the System Grid for an incoming station service supply from the Grid Operator.

iii) Automatic Frequency Response

It is required that Dispatchable Generating Units have continuously fast acting response automatic governor and excitation control systems to control the Generating Unit's power output and voltage levels without instability of operation within the operating range of the unit.

iv) Governor Response Capability

The droop characteristics from no load to full load for Generating Units shall be adjustable in the range of (0 - 5%).

v) Black Start Capability and Dead Bus Control

Some Generating Units shall be designated to have Black Start Capability primarily considering their type and location on the system. This shall enable Generators to restart their facilities without incoming supply from the System Grid, connect to a Dead Bus, and supply load as necessary; once on line Generators are required to be in frequency sensitive mode so as to vary with load changes. In the event of the Generator “black starting” the Grid, the Generator may act, temporarily upon the provision of instructions from the Grid Operator.

The specification of the Black Start Generating Unit shall be a subject of the Interconnection Agreement (normally contained in the PPA as a Schedule) between the Grid Operator and the Generator.

Where a Generator has a facility with a capacity of 60MW (excluding intermittent renewables with high and rapid variability) or greater, at least one source of Black Start supply shall be located at the site. Black Start facilities shall be routinely tested by the Generator to ensure satisfactory operation. The Grid Operator shall have the right to require the Generator to demonstrate the performance of the Black Start Capability. At a minimum, the Generator is required to provide a formal report to the Grid Operator twice a year, detailing the results of the Black Start generator test. One of these reports must be based on a test done in May of that year and shall be submitted to the Grid Operator before June 1 (the official start of the hurricane season). A failed event shall automatically trigger the reporting of that black start test event by the relevant Generator to the Grid Operator. A further report is also to be immediately submitted by the Generator to the Grid Operator upon subsequent successful maintenance and operation of said black start generator.

vi) Fuel Supply Capability (Thermal Plants only)

The Generator shall at its own expense construct and maintain fuel supply infrastructure sufficient to store at least eighteen (18) days of fuel requirement at normal rated output subject to the provisions of Sub-section 3.10.

1.2.4 PROTECTION REQUIREMENTS

- i) Protective systems shall be provided in accordance with the Technical Standards set out in Clause 1.2.1 and Prudent Utility Practice as generally accepted in the power industry.
- ii) All protective relaying equipment shall comply with the appropriate Technical Standards.
- iii) At a minimum, the following protection schemes shall be provided subject to the exigencies of the relevant generation technology including inter alia;

AC generators (Reference is made to IEEE Guidelines 37.102.2006)

- a) Loss of Excitation (Under-reactance type)
- b) Differential current protection (for generator phase-to-phase fault)
- c) Negative phase sequence protection (for unbalanced load operation)
- d) Stator ground fault protection (for generator phase-to-ground faults)
- e) Reverse power protection
- f) Backup protection in the event of circuit breaker failure to operate.
- g) Over- and under-frequency
- h) Over- and under-voltage
- i) Thermal over-load
- j) Rotor (or field) ground fault protection

Transformers (Reference is made to IEEE Guidelines 37.91.2000)

- a) Differential current protection for generator step-up transformers
- b) HV/LV phase and ground overcurrent protection (for station service/unit auxiliary transformers)
- c) Buchholz and/or Sudden pressure (gas relay)
- d) Over excitation protection (for generator step-up transformers)
- e) Backup protection in the event of circuit breaker failure to operate for generator step-up transformers
- f) Over-temperature protection (winding and oil)

Interconnection

- a) Differential (line current high-impedance) for Phase and earth faults.
- b) Backup interconnection protection in the event that external phase and earth faults are not cleared by remote protection system.
- c) Backup protection in the event of circuit breaker failure to operate.

- iv) The protection requirements for the HV interconnection with System Grid will depend on the connection voltage and the Substation configuration. The detailed arrangements for each Generating Facility are set out in the respective Interconnection Agreement. In all cases it should be ensured that each Generating Unit or Facility can be separated from the System Grid as rapidly as possible in the event of a sustained electrical fault on either side of the Interconnection Point. The speed of separation shall be determined by the Interconnection Criteria.
- v) The protective relaying systems shall provide the levels of sensitivity, speed and reliability as required by the Grid Operator. The operation of all protection schemes shall be coordinated with the operation of the Grid Operator's equipment.
- vi) The Generator shall submit the following design data for prior approval by the Grid Operator:
 - a) Protection and Metering single line diagrams;
 - b) Tripping logic diagrams;
 - c) AC and DC schematic diagrams for the interconnection and Generating Unit protection schemes;
 - d) Setting calculations and setting lists for the interconnection and Generating Unit protection schemes including opening/closing time for major circuit breakers; and
 - e) Rating and Transfer Function data as required for computer simulation of the Generating Unit(s). This shall include data on the generator(s), transformer(s), automatic voltage regulator(s) and prime mover governor.
 - f) Substation Equipment single line diagram.

1.3 GRID OPERATOR PERFORMANCE AND TECHNICAL STANDARDS

i) Grid Frequency

The normal operating frequency of the System Grid shall be controlled by the grid operator to be within 50.0 Hz $\pm$ 0.2 Hz.

For the avoidance of doubt, generators shall be designed for sustained operation within the frequency limits as specified in Clause 1.2.2 (i) and for restricted time based operation within the emergency frequency limits as specified in Clause 1.2.2 (ii).

ii) Grid System Voltages

The Nominal Operating Voltages on the System Grid shall be:

- a) 138 kV and 69 kV on the transmission System; and
- b) 24 kV, 13.8 kV, 12 kV, 6.9 kV, 4 kV on the Distribution System.

The Normal Operating voltages shall be within:

- a) $\pm 5\%$ at the Generator Bus;
- b) $\pm 5\%$ on the Transmission System;

The contingency (abnormal) operating voltages shall be within:

- a) $\pm 5\%$ at the Generator Bus;
- b) $\pm 10\%$ on the Transmission System;

iii) Short Circuit Levels

The system shall be designed to withstand a three phase symmetrical short circuit at the Generating Unit Substation for fault levels as specified in the appropriate Technical Standards as set out in Clause 1.2.1.

1.4 OTHER RIGHTS VESTED WITH THE GRID OPERATOR

1.4.1 INSPECTION OF GENERATING PLANT BY GRID OPERATOR

The Grid Operator retains the right to inspect any aspect of the Generator's plant in so far as that plant is pertinent to the provision of capacity and/ or energy to the System Grid, or to the safe and secure operation of the System Grid, in order to verify the correct operation of all equipment including controls, circuit breakers, relays (and relay settings), metering and telemetering. Prior to exercising its right to inspect the Generator's facilities and Metering System, the Grid Operator shall give the Generator two (2) working days' notice and provide adequate reason for the inspection.

The Generator shall keep records to provide verification of tests and maintenance in accordance with agreements between the Grid Operator and Generator.

1.4.2 DISCONNECTION OF GENERATOR BY THE GRID OPERATOR

The Grid Operator retains the right to disconnect any Generating Facility from the System Grid thereby isolating equipment, without prior notice under the following circumstances:

- i) in cases of System Emergency;
- ii) during system restoration following partial or complete loss of power;
- iii) if at any time the Generating Facility is being operated outside acceptable operating parameters in a manner which violates the Connection Conditions set out in the Code or which is likely to cause any of the following:
 - a) A safety risk to personnel;
 - b) Risk to stability or security of the System Grid or Other Generating Units;
 - c) Any behavior causing sustained operation outside the normal System Grid operating frequency and voltages as stated under Sub-section 1.3.

Notwithstanding the forgoing in the event of any material breach of Connection Conditions which prevents the Grid Operator from meeting its Licence obligations, the Grid Operator may disconnect after using best commercial efforts to give notice to the Generator.

2 OPERATIONAL METERING

Adequate Metering Systems consistent with the technical specifications of this clause shall be installed by the Generator. The Metering System shall comprise a Primary and Backup Metering System and shall be designed, financed and installed by the Generator. The Grid Operator shall own and maintain the Primary Metering System while the Generator shall own and maintain the Backup Metering System.

2.1 TECHNICAL STANDARDS FOR OPERATIONAL METERING

2.1.1 LOCATION OF METERING EQUIPMENT

- i) Both Primary and Backup Metering Systems shall be installed to accumulate the outputs and/or inputs at the High Voltage side of the generator step-up transformer.
- ii) Each meter shall have its own current transformer (CT) and potential transformers (PT) and necessary independent systems to function effectively.
- iii) For Generators less than 100 kW, metering requirements of the Standard Offer Contract in addition to the provisions of Clause 2.2.4 of this Code shall apply.

2.1.2 METERING STANDARDS

- i) Instrument transformers shall conform to ANSI Standards C12.11 and C57.14 Class 03 and shall have sufficient capacity to supply the burden produced by the wiring and metering equipment.
- ii) The current transformers secondary winding used for metering purposes shall supply only the metering equipment and associated systems. Notwithstanding the foregoing each current transformer may have other secondary windings that may be used for purposes other than metering.
- iii) Potential transformers' secondary windings may be used for metering and other purposes provided that the total loading does not exceed one half the rating of the transformer.
- iv) Any metering and accumulating equipment shall have sufficient accuracy so that any error resulting from such equipment shall not exceed $\pm 0.5\%$ of full scale ("Allowable Error").

2.1.3 SEALING, FIELD TESTING AND INSPECTION OF METERING SYSTEMS

Meters and associated instrument transformer boxes or enclosures shall be sealed by and at the expense of the Generators at the respective meters. The type of seal shall be approved by the Grid Operator.

For wiring used only for metering purposes, solid metallic conduit runs shall be used to enclose the wiring connecting the instrument transformers and the related accumulating and metering equipment. Any boxes or enclosures or other devices used to join two or more sections of conduit shall be securely covered, fastened and sealed with seals approved by the Grid Operator.

If the wiring used for metering must pass through a panel, panel board or switchgear structure, it shall be fastened together and cabled as a unit separate and apart from the rest of the wiring.

At its own expense, the Generator shall provide any terminal blocks that may be used along the length of the metering conductors within a panel, panel board or switchgear with covers or strips that limit access to the respective connections and said covers or strips shall be affixed with a seal approved by the Grid Operator. Boxes or enclosures shall be sealed with pre-numbered seals approved by the Grid Operator.

Seals shall not be broken by anyone except the Grid Operator's personnel when the meters are to be inspected, tested or adjusted. The Grid Operator shall notify the Generator in advance of such inspection, testing or adjustment, and the Generator has the right to have a representative present.

Before the commissioning of any Generating Unit, the Grid Operator shall test the Metering System for correct wiring and accuracy, using equipment whose accuracy is equal to or better than that of the individual meters. Individual meter components found to be inaccurate before commissioning shall be returned to the Generator for replacement. Malfunctions identified after full acceptance of the Metering System shall be the responsibility of the individual owners.

The Grid Operator shall test the Metering System within ten (10) days after:

- i) The detection of a difference larger than the Allowable Error in the readings of the meters;
- ii) The repair of all or part of a meter caused by the failure of one or more parts to operate in accordance with the specifications; and/or

- iii) Each anniversary of the commissioning date of the unit. If any errors in the readings of the meters are discovered by such testing, the Party owning those meters shall repair, recalibrate or replace those meters and shall give the other Party reasonable advance notice so that the Party receiving notice may have a representative present during any such corrective activity.

2.2 METER READING PROCEDURES

2.2.1 PARAMETERS FOR METER READING

The Generator shall provide and install appropriate equipment and shall make continuous recordings on appropriate magnetic media or equivalent of the Net Energy Output and Dependable Capacity if applicable, of the Generating Unit(s).

The parameters to be metered shall be subjected to the Interconnection Agreement between the Generator and the Grid Operator, and may consist of but not limited to any or all of the following parameters:

- i) Active energy (MWh) OUT;
- ii) Active energy (MWh) IN;
- iii) Reactive energy (MVARh) First Quadrant;
- iv) Reactive energy (MVARh) Fourth Quadrant;
- v) Active Power Demand (MW) OUT;
- vi) Active Power Demand (MW) IN;
- vii) Reactive Power Demand (MVAR) First Quadrant; and
- viii) Reactive Power Demand (MVAR) Fourth Quadrant.

2.2.2 FREQUENCY OF READING

The Demand Interval shall be fifteen (15) minutes and shall be set to start at the beginning of the hour. Demand shall be calculated by averaging the respective parameters over the stated Demand Interval.

The Grid Operator shall read the appropriate meters to prevent clock drift. The clocks shall be checked and reset as agreed by the Parties. If readings are obtained remotely, copies of the data produced by the computer which initiates the reading protocol can be made and provided to the Generator if requested.

2.2.3 CONTROL PROCEDURES

The Grid Operator shall inform the Generator at least 24 hours prior to reading the meters and the Generator shall have the right to have a representative to witness such readings.

For the Demand actually experienced throughout the billing period, the meters shall be equipped with a mass memory module of a minimum of 3 months which shall record the parameters in Clause 2.2.1.

2.2.4 METERING REQUIREMENTS FOR GENERATORS <100 KW

For small Generating Facilities with rated capacity below 100 kW the full metering requirements in Sub-section 2.1 may be reduced. These Facilities will be permitted to be metered using separate import and export meters. The terms and conditions of this arrangement shall be guided by the Standard Offer Contract (SOC).

The metering equipment shall be a bi-directional device or a smart meter having the capability of mass memory, remote reading and power quality monitoring. Specification of the meter shall be provided by the Grid Operator and the Qualifying Entity shall purchase the metering equipment which shall be owned and maintained by the Grid Operator.

2.3 RECONCILIATION PROCEDURES

If the Primary Metering System is known to be inaccurate or otherwise functioning improperly, then the Backup Metering System shall be used during the period that the Primary Metering System is not in service and the provisions described in Sub-section 2.2 shall apply to the reading for the Backup Metering System.

If the Primary Metering System is found to be inaccurate by more than the Allowable Error or to otherwise have functioned improperly during the previous Month, then the correct amount of Net Energy Output and Dependable Capacity for the actual period during which inaccurate measurements, if any, were made shall be determined as follows:

- i) First, the reading of the Backup Metering System shall be utilized to calculate the correct amount of Net Energy Output and Dependable Capacity, unless a test of such Backup Metering System, as required by either Party, reveals that the Backup Metering System is inaccurate by more than the Allowable Error or is otherwise functioning improperly; and

- ii) If the Backup Metering System is not within the acceptable limits of accuracy or is otherwise functioning improperly, then the Generator and the Grid Operator shall jointly prepare a reasonable estimate of the correct reading on the basis of all available information and such guidelines as may have been previously agreed to between the Generator and the Grid Operator. This estimate shall take into account but not be limited to Dispatch Instructions as recorded in the System Control Center dispatch log and meter readings, remote or manual.

2.4 RESOLUTION OF DISPUTES OVER RECORDED METERING DATA

If the Grid Operator and the Generator fail to agree upon an estimate for the correct reading within a reasonable time (as specified in the relevant PPA) of the Dispute being raised, then the matter may be referred for arbitration by either Party in accordance with the relevant PPA.

3 GENERATOR SCHEDULING AND DISPATCH

The Grid Operator is required to operate and maintain a merit order system for Generating Units subject to central dispatch. The scheduling of units for dispatch should be in ascending order of the marginal costs in respect of any hour for the generation and delivery or transfer of electricity into the Grid, to the extent allowed by Transmission System operating constraints and the dynamic operating characteristics of available Generating Units, among other things, based on equal incremental cost principles.

In order to efficiently operate and manage the System Grid in a safe, secure and economic manner, the Grid Operator will require accurate and timely information on the Generating Units' including, availability, efficiency and technical operating capability.

This section outlines the procedures used to determine how individual Generating Units or Facilities are operated in parallel to achieve these objectives based on the information received by the Grid Operator.

3.1 CRITERIA FOR SCHEDULING AND DISPATCH

The Grid Operator shall seek at all times to minimize the variable cost of electricity production subject to constraints of system security, reliability, safety, fuel availability, emission limits and other environmental considerations, and contractual obligations.

3.2 MERIT ORDER SCHEDULING

The Grid Operator shall establish a Merit Order based on the real or contracted Variable Operating Cost component of each Generating Unit or Complex, whichever is applicable.

The Variable Cost of each Generating Unit or Complex is the sum of the Variable Operating & Maintenance Cost (VOM) and the Fuel Cost. In mathematical form:

$$\text{Merit Order Cost (\$/MWh)} = \text{Fuel Cost (\$/MBTU)} \times \text{Full Load Heat Rate (MBTU/MWh)} + \text{VOM (\$/MWh)}$$

The commitment and de-commitment of units in the cost optimization process shall be guided by a number of system parameters including load, available units, the Merit Order Ranking and the forecasted duration. Once committed, the dispatch level of each Generating Unit or Complex shall be determined by the application of equal incremental cost principles as described in Sub-section 3.5.

The Unit Commitment and Generator Scheduling shall be selected for Generation Dispatch in accordance with the Merit Order ranking, subjected but not limited to the following factors for each Generator or Complex:

- i) Real or Contracted Fuel Price
- ii) Real or Contracted Variable Operations and Maintenance Price
- iii) Energy Price
- iv) Declared and projected (MW) capability;
- v) Declared and contracted operating characteristics including inter alia;
- vi) Start-up cost of the units;
- vii) Penalty Factor
- viii) Network Security
- ix) Spinning and Other Operating Reserves

This information allows the Grid Operator to rank the Generating Units in the order of their Full Load Point cost of operation.

Units that have been declared based on their contract, as Take-As-Available, are not influenced by the merit order and equal incremental cost optimization processes. To the extent that a host process, in the case of cogeneration plants, is the driver of the export power to the grid, such an entity shall submit a two (2) week projection of their export expectation to the Grid Operator every Wednesday or within 24 hours of request, such that this information can be used to optimize the expected output of the Dispatchable Generators on the Grid.

3.2.1 REVIEW OF MERIT ORDER AND DISPATCH INPUT

i) Fuel Data

The Merit Order shall be revised on an ongoing basis to reflect the latest available information which includes changes in delivered fuel prices as they occur, consistent with the fuel procurement cycle for each Generating Facility and updates in VOM consistent with the Generator's reporting or business cycle. Updated Merit Order must be declared at the beginning of each Month. Where there is the need to adjust this Merit Order within this monthly cycle the updated Merit Order must be declared within 24 hours of being effected.

Generator shall provide the latest fuel cost and/or VOM information to the Grid Operator for its Generating Facilities within 24 hours of a request or from the time when such information becomes available.

ii) Heat Rate Data

Heat Rate is computed by dividing the total British thermal unit (Btu) content of fuel consumed for electricity generation by the resulting net kilowatt-hour generation. The Basis of the value should always be expressed as either Lower Heating Value (LHV) or Higher Heating Value (HHV). The basis of the heating value provided shall be consistent with the relevant contractual arrangements and the capability of the generation technology employed.

The Heat Rate data for each Generating Unit is necessary to determine its variable fuel operating cost. All contracts for new generating capacity shall have a guaranteed Heat Rate curve or point.

The Heat Rate Tests for each Generating Unit, not having a guaranteed curve or point, shall normally be conducted at least twice annually or as stipulated by contract. The schedules for the Heat Rate Test for all Dispatchable Generating Units shall be developed by the Grid Operator at least one Month before the end of the preceding Year. The Heat Rate Test schedules may be adjusted within the Year to accommodate unforeseen circumstances, subject to agreement between the Generator and the Grid Operator. Such schedules for Heat Rate Test shall be submitted to the OUR by the Grid Operator.

The Heat Rate Test shall be conducted at a minimum of four (4) output levels from the minimum output level to the maximum output level for each Generating Unit.

The Heat Rate information obtained from Heat Rate Tests together with the guaranteed Heat Rates (for units to which this is applicable) shall be used as one of the inputs to the Generator Scheduling and Dispatch optimization process.

If the Grid Operator has sufficient reasons to believe that the Heat Rate of a Generating Unit which does not have a guaranteed curve or point, has changed significantly within the Month or since the last test (due to rehabilitation, damage etc.) the Grid Operator may request the Generator to conduct a Heat Rate Test in accordance with the JPS Heat Rate Testing Policy (in the case of JPS owned generators) or other approved policy (in the case of non-JPS generators) and update the Heat Rate curve for such a Generating Unit. All cost associated with the Heat Rate test shall be the responsibility of the Generator.

The Generator may request a heat rate test of its own unit if it can provide information to substantiate that it has made improvements in the performance of its Unit(s). No more than two such requests will be accommodated within any calendar year.

Heat Rate Tests for all Generating Units, including those of the Grid Operator, shall be coordinated (mutually agreed date) by the System Control Engineer. The Grid Operator shall reserve the right to witness all such tests.

The OUR shall be advised and duly notified beforehand when such tests are contemplated and carried out and reserves the right to witness all such tests.

In the case of Independent Power Producers, the information on which the Generating Units will be ranked shall be based on the contractually agreed performance or such other criteria as established through the Power Purchase Agreement between the Generator and the Grid Operator.

3.3 NOTIFICATION OF MERIT ORDER

- i) The Grid Operator shall notify the Generator as to the relative position of its dispatch-able Generating Unit(s) in the Merit Order in terms of ranking number each Month.
- ii) The Grid Operator shall notify the OUR of the daily revised Unit Commitment Schedule and the actual dispatch for the prior twenty four (24) hours.

3.4 SYSTEM SECURITY STANDARDS

3.4.1 SPINNING RESERVE

The Grid Operator shall carry a minimum Spinning Reserve margin as set out in Schedule D of this Code. The determination of the Spinning Reserve margin shall be based on economics and System Security considerations.

The Grid Operator may from time to time adjust its Spinning Reserve policy subject to the approval of the OUR. Before such approval can be granted, the Grid Operator shall submit the revised Spinning Reserve policy to the OUR for review, analysis and determination.

3.4.2 OPERATING RESERVE

The Grid Operator shall co-ordinate Scheduled Outages such that the Ten Minute Reserve margin and the Operating Reserve margin are maintained at or above the level set out in Schedule D. This shall allow the System Grid to be able to accommodate one of the largest Generating Units being forced out of service and still maintain adequate available Capacity to meet System Demand.

- a) The Ten Minute Reserve margin shall comprise units which are able to be synchronized and provide real power within 10 minutes.
- b) In the case of System Emergency and unplanned outages, the Scheduled Outages of Generating Units shall be rescheduled if possible to maintain this reserve margin.

3.5 UNIT COMMITMENT SCHEDULING AND SYSTEM OPERATION

It is the Grid Operator's obligation to prepare a Unit Commitment Schedule which reasonably reflects the likely System conditions. This schedule shall be prepared for the following Week and revised on a daily basis, except for weekend days and public holidays. The scheduling of Generating Units shall be in accordance with the latest available information, subject to relevant technical constraints specified in Sub-section 3.2.

Each Generator must submit to the System Control Center by approved communication means a declaration of plant availability and capability, and any other information as agreed between the Generator and the Grid Operator from time to time. This data is to be declared to the Grid Operator in order to facilitate the timely preparation of a Unit Commitment Schedule.

A Weekly Unit Commitment Schedule shall not be regarded by any Generator to be Dispatch Instructions but shall be provided as a service to Generators for planning purposes.

The daily revision of the Unit Commitment Schedule shall at all times take precedence over the short-term predictions.

3.5.1 PREPARATION OF UNIT COMMITMENT SCHEDULE

In the preparation of Unit Commitment Schedule, the Grid Operator shall take into consideration, among other things pertinent to commitment schedule, the following factors:

- i) forecasted Demand and geographical Demand distribution;
- ii) each Generator's declaration of each Generating Unit(s) MW capability and availability;
- iii) Generator's contracted operating characteristics;
- iv) contracted and declared Heat Rate curve or point;
- v) fuel prices and constraints;

- vi) System reserve requirements;
- vii) System Stability implications, frequency and voltage control; and
- viii) System Grid constraints.

Monday - Friday: The daily schedule of expected availability and Generation Dispatch shall be prepared by System Control Center and made available to the System Control Engineer by 1 p.m. each day for the 24 hour period starting 1 p.m. to 1 p.m. the following day. This shall be reviewed by 1 p.m. on the following day.

Saturday-Sunday: The daily schedule of expected availability and generation levels for the weekend shall be done and made available to the System Control Engineer by 1 p.m. on the Friday preceding the weekend. This schedule shall cover the period from Friday 1 p.m. to Monday 1 p.m. and shall be reviewed by 1 p.m. on the Monday afternoon.

To facilitate preparation of these schedules, the Generator shall make a declaration of plant availability and capability over the scheduled period and any other information, as agreed between the Generator and the Grid Operator from time to time for remaining hours in the current day starting at 11 am.

The specific procedure for receiving data and making notification of commitment of Generating Units for dispatch shall be based on the following:

- i) An agreed and approved means of communication between the Generator and System Control Engineer with adequate backup in case of the failure of this approved means; and
- ii) In order to ensure rapid transfer of information an interim declaration shall normally be verbally submitted in the first instance and shall be confirmed by the approved means without delay.

Where a Generator becomes aware of any changes in these declared values or other data subsequent to the declaration, then the Generator shall without delay notify the System Control Engineer.

3.6 DISPATCH INSTRUCTIONS

This clause sets out the procedures for issuing Dispatch Instructions to Dispatchable Generating Units and the responsibilities of the System Control Engineer and the Generating Unit Controllers in the minute to minute control time frame.

Real Power (MW)

Real Power (MW) dispatch shall be based on an Equal Incremental Cost principle to minimize the variable operating cost, subject to the considerations specified in Subsections 3.2, 3.4 and Clause 3.5.1 respectively. Dispatch Instructions are normally given on a half hourly basis or anytime that is warranted by the operational requirements of the System.

The Equal Incremental Cost Principle states that, to achieve the most economic dispatch of power generation each Generating Unit on line, should operate at the same System wide point of Incremental Cost to serve a given load, unless the limit of capacity of a Generating Unit or other imposed constraints prevents it from reaching that cost. The Incremental Cost is the cost required to produce an additional MWh of energy above a base amount.

Reactive Power (MVAR)

Reactive Power (MVAR) is dispatched at the discretion of System Control Engineer to maintain the System voltage within the tolerable limits. Under normal operating conditions Generating Units operate at 0.85 pf but could be required to operate at as low as 0.8 pf and can be requested to absorb reactive power, within the minimum functional specification of the units.

In instances when the Grid Operator makes the request for the Generator to absorb VARS, the Generator should not be penalized on their electricity bill during that period, to the extent that the absorption of reactive power has affected the ratcheting mechanism.

All Generators are required to provide the generator capability curve for the unit upon request by the Grid Operator. The Grid Operator shall at all times use the most economical choice available to manage the system voltage.

Ancillary Service

The Grid Operator subject to the approval of the OUR may contract with suitably qualified Generators for ancillary services (Voltage Support, Frequency Control, Reserve Support, etc.) to the extent that it does not violate the Power Purchase Agreements.

3.6.1 INSTRUCTION TO SYNCHRONIZE / DESYNCHRONIZE

The times at which a Generator shall be synchronized and desynchronized shall be directed by the System Control Engineer.

3.6.2 FREQUENCY AND VOLTAGE CONTROL

Adherence to the frequency and voltage standards shall be the responsibility of the System Control Engineer who shall issue to each Generator the required Dispatch Instructions for both Real Power (MW) and Reactive Power (MVAR) output or absorption in the case of Reactive Power, in accordance with the declared operating limits of each Generating Unit as agreed upon between the Grid Operator and the Generators to ensure adherence to these operating standards.

Automatic Generation Control (AGC) can be used to perform frequency control by sending signals to generator to adjust output. To the extent that the application of AGC is deemed economically feasible to the consumer and technically possible based on the specific generator capability and/or its expected operating regime, each new Generator shall ensure that the Generating Units are AGC enabled and can, without human intervention, accept and respond to a signal to adjust load. Additionally, the SCADA/EMS system shall have the capability to facilitate the use of AGC. The range of control afforded by the implementation of AGC shall be the subject of the Generator's PPA.

System Control Centre Responsibility

The System Control Engineer shall be responsible for issuing any instruction necessary to:

- i) Maintain the voltage on the Transmission System in accordance with the normal operational limits of $\pm 5\%$;
- ii) Maintain, or enable others to maintain, the voltage of supply to consumers within the limits of $\pm 5\%$ of the Nominal Operating Voltages;
- iii) Supply the Reactive Power requirements of the System as economically as possible, and to organize the disposition of Reactive Power reserves for proper control of the System voltage in accordance with the requirement of i) and ii) above;
- iv) Maintain frequency within the limits of 50 Hz ± 0.2 Hz

- v) Designate Generating Units to operate in Dispatch or Spinning Reserve mode

Generator Responsibility

The Generating Unit Controller shall be responsible for:

- i) Ensuring that the Generating Unit's mode of operation is as designated by the System Control Engineer;
- ii) Ensuring that Generating Units operate in active power frequency control mode followed only by frequency control mode when in emergency/abnormal conditions unless operation in this mode has been agreed as being impracticable between the Generator and the Grid Operator;
- iii) Ensuring that Generating Unit(s) automatic voltage regulators are in service continuously. The System Control Engineer shall be informed whenever a Generating Unit is operating without its automatic voltage regulator or Reactive Power limiter; and
- iv) Notifying immediately the System Control Engineer of any unusual voltage, frequency or power condition or any dynamic disturbances occurring upon any Generating Unit.

In the event of a sudden change in System voltage a Generating Unit Controller shall not take action to override automatic Reactive Power generation response, unless instructed otherwise by the System Control Engineer or unless immediate action is necessary to comply with stability limits or declared constraints of plant apparatus.

3.6.3 CHANGES TO GENERATION CONDITIONS

The Generator shall notify the Grid Operator as soon as possible of any factors which will or are likely to, affect the power output capability, flexibility, response or cost of production of any of its Generating Units.

Generating Units and apparatus shall not be taken out of service or rendered unavailable without reference to the Grid Operator except in cases of Emergency. In such cases the System Control Engineer shall be informed as soon as possible of the action taken.

A Generator experiencing an unplanned outage of any of its Generating Units shall inform the Grid Operator as soon as possible of all relevant details concerning this outage. As soon as the cause of the outage has been properly assessed and a recovery plan established, the Generator shall inform the Grid Operator of the expected time and the condition under which the Generating Unit shall return to service.

The actual time that the outage occurred and the Generating Unit was returned to service and any other information deemed to be important in relation to the outage shall be logged by the System Control Engineer.

3.7 SWITCHING INSTRUCTIONS

High Voltage switching shall only be carried out with the permission of the System Control Engineer except for agreed routine switching or in case of System Emergencies. Persons required to carry out high voltage switching must be specifically certified and authorized by the Grid Operator to carry out such switching.

The following procedures shall be adhered to when carrying out complex switching operations:

- i) When switchgear, normally operated to the instruction of the System Control Engineer has been operated without instruction from him, the operator concerned shall notify the System Control Engineer immediately. Switchgear normally operated to the instruction of the System Control Engineer shall not be closed without his permission;
- ii) the System Control Engineer shall ensure that any instruction for switching issued by him is repeated phrase by phrase as received and at the termination of the message is read back to him in full by the recipient; and
- iii) Any instruction issued by the System Control Engineer relating to the operation of switchgear shall, be written down and every such instruction shall be repeated phrase by phrase as received. At the termination of the message it shall be read back in full to sender to ensure that the instruction has been accurately received.

Instructions from the System Control Engineer shall be carried out without delay and at the time of completing, the operation or sequence of operations shall be reported back to the System Control Engineer.

An operator shall inform the System Control Engineer immediately of any objection to any instruction. The System Control Engineer shall then investigate the matter and if necessary refer it to higher authority endowed with the necessary powers of authority, to make a determination on such matters.

3.8 NON CENTRALLY DISPATCHED PLANT

Non Dispatchable Generating Units shall operate as agreed upon between the Grid Operator and the Generator. The Grid Operator shall inform such Generators where there is a need for outage on the Generating Unit or of any incident which would affect the operations or safety of the Generating Unit. During an Emergency, or where there is life and property at risk, the Grid Operator and/or the Generator reserves the right to disconnect and so isolate any Generating Unit without prior notification. However, both parties must communicate immediately once the risk has been neutralized, to inform of the action taken and why it was necessary to take such action without prior notice.

The Generator shall communicate with the System Control Engineer on matters of switching and Synchronization during normal operations and in the event of System Emergency.

3.9 COMMUNICATION AND REPORTING

The Generator is required to provide information as requested, pertaining to the operation of their Generating Unit(s).

3.9.1 DESIGNATED CONTACT PERSONS

The Grid Operator shall at all times have a person designated as the System Control Engineer.

Each Generator shall at all times have a person designated as the Generating Unit Controller in charge of operation and control of each Generating Unit.

3.9.2 SYSTEM CONTROL CENTER RECORD OF DISPATCH

A record of events shall be kept at the System Control Center, which shall include, but not be limited to:

- i) All instructions regarding switching, voltage control and Generating Unit operation;
- ii) Deviations in frequency outside the normal range;

- iii) Each operation or sequence of operations of circuit breakers, disconnectors and earthing switches under the control of the System Control Engineer and, where appropriate, alarms and protection indications;
- iv) Transformer tap changers instructed or operated by the System Control Engineer;
- v) The synchronization or taking off-line of Generating Units;
- vi) Details of the application and removal of main short and grounds and other safety precautions, including the issue and cancellation of safety documents and HV live line working certificates, by the System Control Engineer or his designate as required by the Grid Operator's safety rules;
- vii) The commissioning, taking out of service or re-commissioning of plant and apparatus, including automatic switching systems, protection and changes to relay settings, together with relevant details;
- viii) The failure, or change of state, of plant or apparatus on the System Grid together with relevant details;
- ix) The failure of plant or apparatus affecting the availability of Generating Unit(s), together with relevant details;
- x) The location and identification of switchgear for which a risk of trip is expected;
- xi) Generating Units which are not operating in the frequency sensitive mode;
- xii) Any significant abnormal or dangerous occurrence in operation including incidents involving the use of emergency public service;
- xiii) Any interruption and restoration of supply together with relevant details;
- xiv) Details of the Grid Operator System load reductions, restorations and Demand control;
- xv) System/ standard time deviation at 7:30 a.m. Eastern Standard Time and 9:30 p.m. Eastern Standard Time or as may be required.

3.9.3 GENERATOR OPERATIONS LOG

The Generator shall maintain an accurate and up-to-date Operations Log. The purpose of this Operations Log is to record significant events, plans, requests and instructions. Entries into the Operations Log should be made on a daily basis and should include, as necessary, the following:

- i) Dispatching Instructions and times of receipt of such instructions from the System Control Engineer;
- ii) Time of implementation of instructions;
- iii) Any request from the Generator to the System Control Engineer which includes:
 - a) Scheduled outages;
 - b) Forced outages;
 - c) Load adjustments;
 - d) Maintenance Outages;
 - e) Emergencies of any kind affecting the operation of the Generating Facility;
and
 - f) Daily available Capacity.
- iv) Names and status of all personnel on each shift;
- v) Daily midnight readings of the fuel used and in stock;
- vi) Statements relating to abnormal running conditions of Generating Unit(s) and auxiliaries;
- vii) All Real (kW) and Reactive (KVAR) Power at half hour intervals, frequency and voltage, at the 69 kV busbar and 138 kV busbar at half hour intervals, unit auxiliary and station busbar voltage and real and reactive power; any units connected at the distribution level should record similar information at the connected busbar.

Generating Facilities operating on an energy-only basis with installed capacity below 15MW may not be manned at all hours and hence may not record these parameters immediately at every half hour. For these types of Generators, adequate SCADA infrastructure shall be put in place by the Generator for remote

monitoring of said parameters by the Generator and Grid Operator, as well as local real time data capture and storage of the above parameters by the Generator.

- viii) Time of trip-out or removal of Generating Units from service and the time of return to service; and
- ix) Visits by factory inspectors to the Generating Facility.

3.10 FUEL SUPPLY AGREEMENT

The Fuel Supply Agreement shall:

- i) Demonstrate a dependable and sufficient fuel supply;
- ii) Detail the infrastructure installed for delivery of the fuel from the central storage point to the plant gate;
- iii) Provide mitigating strategies in the event of natural disaster affecting the supply of fuel delivery to Jamaica;
- iv) Detail Fuel Transportation Agreement; and
- v) Detail alternative fuel supply arrangements and infrastructure requirements.

All Generators shall be required to:

- i) Obtain and maintain reliable supply of fuel (on-site storage exclusive to the Generating Facility) of quality and quantity sufficient to generate the Dependable Capacity and the Net Energy Output requirements of their Generating Facilities for a period of at least eighteen (18) days and the minimum inventory level should be 7-10 days. Note that the Grid Operator must canvas the Generators to obtain the inventory levels and advise the Generator to evaluate available options if the levels are below required levels or trending negatively for uninterrupted operations. The Grid Operator shall seek permission via an application to the OUR to trigger an emergency plan.
- ii) Provide the Grid Operator the Fuel Supply Plan; as duly approved by the OUR, in consultation with the Grid Operator.
- iii) Only enter into fuel supply arrangements consistent with the Fuel Supply Plan.

3.11 GENERATOR SCHEDULING & DISPATCHING TOOLS

The Grid Operator is required to ensure consistency and objectivity in the decision-making mechanisms used. These mechanisms may be in the form of standardized procedures and/or computational systems.

The Grid Operator is responsible for updating the System Control Policy & Procedures as required, due to changes in the system characteristics or international best practices, where it has relevance to the Jamaican Electric Power Grid. Documentation of the procedures followed in making System operations decisions must be promulgated to individual Generators after ratification by the OUR.

The tools used to assist in the Generator Scheduling and Dispatch optimization process must be based on an internationally accepted optimization algorithm. The tools must be used in accordance with its intended design and the Grid Operator is responsible for ensuring that it is functional and accurate.

3.12 TRANSPARENCY AND FAIRNESS

In order to assure transparency and fairness while being cognizant of the confidentiality provisions in individual contracts, the following outlines how and what type of information will be shared among stakeholders in the generation market. Unless explicitly stated otherwise in the document, the following shall prevail:

- i) **The Regulator:** The OUR shall be allowed access to any and all available information it requires from both the individual Generators or Complex, and the Grid Operator. Periodically as agreed between the Grid Operator and the OUR, Technical Reports will be compiled by the Grid Operator and provided to the OUR, and will contain information from the logged system parameters as agreed from time to time.
- ii) **Individual Generator:** The Grid Operator is required to provide, in a timely manner, individual Generators with any technical system information that affects the operation of interconnected Generating Units for example, fault information should be shared with all Generators, with due consideration of the specific confidentiality provisions contained in each PPA and Licence.
- iii) **Grid Operator:** The Grid Operator shall have timely access to all information it reasonably requires from the individual Generators.

3.13 NEW TECHNOLOGIES

New generation technologies that have parameters not covered by this Code may be given consideration for inclusion to the Grid. However, the OUR, in full consultation with the Grid Operator, shall first provide written approval of the technical compatibility of the technology with the Grid, before the new technology can be interconnected.

4 LOAD SHEDDING AND POWER RESTORATION

4.1 LOAD SHEDDING PROCEDURES

4.1.1 UNDER FREQUENCY (AUTOMATIC) LOAD SHEDDING

During incidents in which the frequency decay is such that the Generating Units' governors cannot adequately compensate for the decay, the Under-Frequency Load Shedding Scheme is designed to shed the appropriate amount of Load to improve the System frequency so as to prevent damage to the Generating Unit(s) and/or collapse of the Power System.

The Grid Operator shall provide the OUR with the details of the Under-Frequency Load Shedding Scheme which may be in force from time to time and contemporaneously with any relevant changes that may apply.

Low Frequency Alarms

Low frequency alarm relays shall be installed in power station control rooms and shall be set at 49.5 Hz. These alarms will warn Generating Unit Controllers of low frequency problems, but no action shall be taken without verification from the System frequency meter at the System Control Center.

Low frequency alarm relay shall be installed in the System Control Center and shall similarly be set at 49.5 Hz.

Action at Low Frequency Alarms

At a low frequency alarm, Generating Unit Controllers shall confirm:

- i) That the alarm is genuine by reading the analog and digital frequency meters/charts; and
- ii) Whether the System is still interconnected and whether the alarm is for the entire System or section(s) thereof.

At the first stage alarm the Generating Unit Controller shall not act to restore the System frequency without prior consultation of the System Control Engineer.

The exception of this rule is allowed when the decay in System frequency results from a loss in Generating Unit output, in which case the appropriate Generating Unit Controllers

shall act to restore its former level of output. The System Control Engineer must be informed as soon as possible thereafter.

Action Below 49.5 Hz

At 49.5 Hz and falling the Generating Unit Controller shall act to increase Generating Unit output within operating limits, in order to restore the System frequency and then report action taken to the System Control Engineer.

To help relieve the System overload, the System Control Engineer may carry out further manual load shedding in accordance with Clause 4.1.2.

Action at 48.0 Hz and Falling

In order to save the System from total collapse and prolonged outage, the circuit breakers of the affected Generating Units shall be opened.

The auxiliaries, however, should be on 'unit supply' as the objective is not to trip the Generating Unit but to remove it from the System with it operating on its own unit auxiliary power.

After a total System failure is confirmed Generating Units shall be black started as quickly as possible to be ready to restore supply as instructed by the System Control Engineer in accordance with black start procedures.

Should a System failure occur, restoration of the System shall commence as soon as possible in accordance with the procedures set out in Sub-section 4.2.

4.1.2 MANUAL LOAD SHEDDING

Where there is insufficient generation to meet the Load it may be necessary for the Grid Operator to institute Load Shedding on a programmed basis. When it is known that generation deficiency will extend over a period of several hours or days, particularly during Peak Hours, such Load Shedding shall be done in blocks consisting of a number of feeders supplying various sections of the System, usually for 1 to 4 hour periods. The Load represented by the blocks shall be arranged to equate the amount of Load shed with the extent of the known generation deficiency and also to equitably distribute the time and period of Load Shedding among the blocks.

A manual Load Shedding procedure may be implemented to rotate the blocks shed after Under-Frequency Load Shedding has taken place. Manual Load Shedding may also be implemented to prevent further Under-Frequency Load Shedding.

Every effort must be made to ensure that the programmed duration of each outage is maintained as near as possible to the planned schedule or for a shorter duration where possible.

Feeders supplying critical Loads should be identified and whenever possible the shedding of these feeders should be avoided.

If the shedding of feeders supplying hospitals and other critical Loads become necessary the following actions must be taken by the Grid Operator prior to effecting this measure:

- i) alert the hospital(s) and critical Loads supplied from the feeder(s); and
- ii) advise hospital staff to activate stand-by plant if available.

In order to maintain supplies to the maximum number of consumers permitted by available Generating Capacity, the System Control Engineer shall, whenever possible, avoid shedding a complete block of Load when a portion thereof will provide the necessary relief to the Generating Units. The Load Shedding log sheet shall be properly completed.

To achieve Load reduction and upon consultation with higher authority, the System Control Engineer may decide to change the target frequency from 50.0 Hz to a minimum of 49.6 Hz. or reduce busbar voltages by up to 4% if necessary at all Generating Facilities.

It should be noted that Substation locations having automatic on-load tap changers will attempt to maintain normal voltage. The result of busbar voltage reduction shall be carefully noted.

Any adverse effect of changing target frequencies and/or voltages on any Generating Unit shall be reported to the System Control Engineer immediately who shall take the necessary corrective action.

4.2 CONTINGENCY PLANS FOR POWER RESTORATION

4.2.1 PROCEDURES FOR RESTORATION OF POWER FOLLOWING WIDESPREAD BLACKOUT

The System Control Center is responsible for coordinating all activities required to restore the System following partial or total System shutdown.

During the event of a total System shutdown the following procedures shall apply to restore power System-wide:

- i) designate Generating Units with Black Start Capabilities to commence restoration;
- ii) restart these designated Generating Units;
- iii) establish a transmission line pathway to the nearest other Generating Unit which is to be restarted while clearing all Load in this pathway;
- iv) establish a manageable distribution load preferably adjacent to the Generating Unit;
- v) start and synchronize the Generating Unit;
- vi) repeat procedures (iv) to (v) above until all Generating Units required to restore power are brought back into service; and
- vii) gradually return Load to the System while ramping up the power output of the Generating Units until the System is totally restored.

Procedures (iv) to (vii) shall be used to restore the System after partial System shutdown. For detailed information on System restoration procedures refer to the Grid Operator's System Restoration Policy and Procedures.

5 GENERATOR MAINTENANCE PLANNING

5.1 LONG TERM MAINTENANCE

5.1.1 PLANNING HORIZON

The Grid Operator shall develop an overall generation maintenance plan for three (3) years in advance. The first year shall be sufficiently detailed with less detail for the following years 2 and 3. The plan which shall incorporate statutory maintenance requirements shall be reviewed annually and updated as may be necessary.

To achieve this objective, Generators shall submit to the Grid Operator on or before the first day of July of each year a rolling three year plan for the scheduled maintenance requirement for their facility beginning in January of the following year. The Grid Operator shall submit the finalized, overall generation maintenance plan to the OUR by January 1 of each year and each Generator shall submit its final generation maintenance plan to the OUR by January 1 of each year.

The Grid Operator shall schedule both long and short term Maintenance Outages in a non-discriminatory manner as far as System security constraints reasonably allow. Both Grid Operator and Generator shall ensure that interconnection and other related facilities are maintained within the periods stipulated for scheduled maintenance of the Generating Facility, given the relevant technical constraints.

5.1.2 ANNUAL COMMITMENT OF MAINTENANCE PROGRAM

Generators shall submit to Grid Operator on or before the first day of July of each Year, a schedule (the 'Maintenance Schedule') describing the proposed availability of the Generating Facility for each Month of the twelve (12) Month period beginning with January of the following Year. The Maintenance Schedule shall indicate the Generators' preferred dates and durations of all scheduled maintenance. In developing the plan the Grid Operator shall take into account the manufactures recommendations for maintenance of the plant.

The Grid Operator shall notify Generators in writing whether the scheduled maintenance periods requested on the Maintenance Schedule are acceptable. The Grid Operator shall have the right to request the Generators to conduct scheduled maintenance during periods other than those indicated in the Maintenance Schedule, provided that the period specified by the Grid Operator shall be as close as reasonably practicable to the periods requested by the Generators, shall be of equal duration as the periods requested by the

Generator and shall be within the range of time periods identified by the Generator as the range of time periods within which such scheduled maintenance must be performed in accordance with the manufacturer's recommendations for the Generating Facility.

5.1.3 CHANGES TO THE COMMITTED MAINTENANCE SCHEDULES

Committed Generating Unit Maintenance Schedules shall be strictly adhered to unless unanticipated circumstances may mean interruption of supply to customers or a compromise in System security if the Maintenance Schedule is not adjusted. Under such circumstances both the Grid Operator and the Generator shall make best efforts to reschedule the outage as follows:

- i) Grid Operator may upon five (5) days prior notice request Generator to reschedule a scheduled maintenance provided, however, that Grid Operator shall not request that scheduled maintenance be rescheduled to a time that is outside of the range of time periods identified by the Generator as the range of time periods within which such scheduled maintenance must be performed in accordance with the manufacturers recommendations for the Generating Facility;
- ii) Generator may, upon five (5) days prior written notice, request that it be permitted to conduct additional scheduled maintenance for a period not identified in the Maintenance Schedule if the maintenance to be conducted cannot be postponed until the next period of scheduled maintenance identified on the Maintenance Schedules without damaging or otherwise threatening the Generating Facilities. Generator's request shall also identify the range of time periods within which such additional scheduled maintenance shall be performed in order to avoid damaging or otherwise threatening the Generating Facilities. Grid Operator may upon three (3) days prior written notice, request Generator to reschedule such additional scheduled maintenance; provided, however, that Grid Operator shall not request that such additional scheduled maintenance be rescheduled to a time that is outside of the time periods identified by the Generator as the range of time period within which such additional scheduled maintenance shall be performed in order to avoid damaging or otherwise threatening the Generating Facilities.
- iii) If the Generator is inside a scheduled maintenance period and requires an extension of the maintenance period, the Grid Operator shall have the right to review and determine if the extension can be accommodated or the extended work period is to be classified as Forced Outage.

5.2 SHORT TERM OUTAGE PROGRAM

For short term outages Generators shall give the Grid Operator at least two (2) hours' notice prior to taking the Generating Facilities out of service.

The granting of such outages shall be at the sole discretion of the Grid Operator.

6 TESTING AND MONITORING

6.1 PROCEDURES FOR CONDUCTING TESTS

The Generator shall provide to the Grid Operator a timetable and a list of all tests to be performed on the Generating Units, and such tests shall be subject to approval by the Grid Operator. The Grid Operator shall be given five (5) days' notice of any testing and shall reserve the right to have a representative present during any such tests.

6.2 STANDARD TESTS

This section addresses procedures for testing and monitoring of Generating Units for purposes of determining available Capacity and, if relevant, operating characteristics in accordance with the commercial and technical conditions of Power Purchase Agreements. An Independent Engineer shall be required for the commissioning of new Generating Facilities.

6.2.1 TEST PRIOR TO FIRST SYNCHRONIZATION

i) Mandatory Tests that may be carried out at the Factory prior to Equipment delivery at the Site of the New Generator Facility

- a) Automatic Voltage Regulator (AVR) setting up and adjusting with the Generator running at rated load;
- b) prime mover governor control checks;
- c) open and short circuit tests on the generator as per IEC 60034 or equivalent under the standard bodies of Clause 1.2.1; and
- d) Governor tests for units not allowed to perform full load rejection tests under Clause 6.2.2 (viii)

In each instance, the Generator shall provide the Grid Operator with the results of all such tests, within a reasonable time of the test being completed.

ii) Tests that shall be completed at the Site of New Generating Facility

- a) Grounding test at the generator switchyard;

- b) functional testing and timing of High Voltage switchgear in the Substation;
- c) voltage phasing checks between the Substation to which the Generating Unit is connected and the System Grid;
- d) primary and/or secondary injection tests and functional tests to prove the calibration and function of all electrical protection schemes installed for the Generating Unit(s) and the Facility.

Upon completion of each test the Generator shall within forty eight (48) hours provide the Grid Operator with two (2) copies of the results of such tests.

The Grid Operator shall have the right to request additional testing if, in its judgment verified by an Independent Engineer, any test results are not satisfactory for establishing the purpose for which the test was intended. Such additional testing shall be performed at the Generator's expense.

The Generator shall confirm to the Grid Operator the programme for any test as specified or advise of any adjustments thereto, not less than five (5) days prior to the commencement.

6.2.2 TESTS AFTER FIRST SYNCHRONIZATION

After the Pre-Synchronization tests as defined in Sub-section 6.2 and prior to the commissioning date, and under such subsequent conditions as defined by Power Purchase Agreements, Generator shall carry out the following tests at the Generator's expense:

i) Dependable Capacity

The Generator shall test the Dependable Capacity of the Generating Unit. The test shall be performed according to ASME, IEEE, ISO, and NEMA standards or to equivalent standards of Clause 1.2.1. If any such standards are inconsistent in any respect, the test shall be performed in accordance with the most stringent standard.

ii) Reliability Run

The Generator shall test the Reliability of the Generating Units in accordance with industry standards based on the type of plant and established international codes for the industry.

iii) Automatic Voltage Regulator (AVR) Droop

The Generator shall test the AVR to demonstrate control of the Generating Unit voltage over the range of plus or minus five (± 5) percent of rated voltage with a droop characteristic of plus or minus one half (± 0.5) percent.

iv) Governor Operation

The Generator shall demonstrate that the speed governor for each Generating Unit operates over its range, the droop being adjustable from two (2) percent to five (5) percent.

v) Reactive Capacity

The Generator shall test each Generating Unit's capability to operate at rated voltage and frequency at power factors and under reactive conditions according to the technology used. Where synchronous generators are used, the minimum capabilities shall be as follows:

100% output : 0.80 lag; 0.99 lead

vi) Short-term Load Capability

The Generator shall test each Generating Unit's capability to operate at a maximum safe load of one hundred and ten percent (110%) of the Required Dependable Capacity for at least one (1) hour. Where the Generating Unit cannot undergo a "Rapid Start", this unit must also be able to operate at a minimum safe load of at least zero (0) percent of the Dependable Capacity (0 MW) for one (1) hour.

vii) Response of Unit to Step Load Changes

For prime mover technologies that allow controllable load changes, the Generator shall test the capability of each Generating Unit to increase load by steps.

viii) Full Load Rejection

The Generator shall test the capability of each Generating Unit and auxiliaries to withstand 'Partial Load Rejection,' while remaining in a safe condition and without initiating a trip of the Generating Unit. Where a Generating Unit cannot undergo a Rapid Start, the Generator shall also test and prove the capability for each Generating Unit to withstand 'Full Load Rejection' while remaining in a safe condition and without initiating a trip of the Generating Unit.

Where a Co-Generator may determine that a Full Load Rejection test may cause a severe disruption of the Co-Generator's process operations, then a Partial Load Rejection test at a load value capable of being managed by its process operations shall be conducted instead.

ix) Thermal Performance Tests

The Generator shall test the Heat Rate of each Generating Unit and shall be conducted according to Clause 3.2.2 (ii).

The Grid Operator shall have the right to request additional testing if, in its judgment verified by an Independent Engineer, any test results are not satisfactory for establishing the purpose for which the test was intended. Such additional testing shall be performed at the Generator's expense. The results of the immediately prior test shall govern until the additional test is completed. The results of the additional test shall supersede the prior test for all purposes commencing on the day following the additional test.

The Generator shall notify the Grid Operator of the proposed programme for any test specified in this Section, or advise of any adjustments thereto, not less than five (5) days prior to the proposed commencement of the relevant test. Upon receiving such notice, the Grid Operator shall have the right to reschedule the commencement of such test; provided that the rescheduled commencement shall not be more than three (3) days before the proposed commencement nor more than ten (10) days after the proposed commencement. The Grid Operator shall be entitled to have representatives present for the purpose of observing any such test. The OUR shall be notified beforehand by the Generator of all test programmes and shall have the right to have Officers present for the purpose of observing any such test.

Upon completion of each test specified in this Section, The Generator shall promptly provide the Grid Operator with two (2) copies of the results of such test, which shall be copied to the OUR; provided that the Generator shall submit all such test results to the Grid Operator no later than ninety (90) days after the commissioned date of the relevant Generating Unit or Facility.

6.3 CO-GENERATORS AND NON-DISPATCHABLE GENERATORS

Co-Generators and Generators with Non-Dispatchable Generating Units shall be required to perform all tests as listed in Sub-section 6.2.

6.4 TESTING OF METERING SYSTEM

These testing procedures are outlined in Section 2 of this Code.

6.5 PARAMETERS MONITORING

For modeling of the Grid, Generators shall be required to periodically (5-10 years) submit the Generator operating parameters to determine if there is any decay which should be modeled.

Generators shall carryout routine and prototype response tests on excitation systems and governor systems (unit frequency response) for new power stations coming on-line or power stations at which major refurbishment or upgrades of these systems have taken place. Routine review is required of all power stations at least once every five (5) years.

7 GENERAL PROVISIONS

7.1 MATTERS TO BE AGREED

7.1.1 OUR RULINGS AND DIRECTIONS

In the event of any conflict between the provisions of the Code and any direction or ruling issued by the OUR, such direction or ruling shall prevail. No Party to this Code shall be deemed to be in non-compliance of this Code for failing to comply with the conflicting provisions.

7.1.2 OTHER AGREEMENTS

It is recognized that existing Power Purchase Agreements contain clauses which may in a number of situations overlap with provisions of the Code. However, in the event of any conflict between the provisions of this code and any other commercial bilateral agreements on system operations and security, the provisions of the PPA shall have precedence over the Code bearing in mind that any new PPA shall be subject to the terms and conditions of the Code.

Where it is clearly undesirable to disturb the existing commercial contracts to effect compliance with this Code, the procedures for exemption from the conflicting provisions shall be followed as outlined in Sub-sections 7.4 and 7.5 respectively.

Notwithstanding the above provisions, Generators existing prior to the promulgation of the Code other than those bound by PPAs shall be given the option to adopt or make arrangements to comply with the Code. New Power Purchase Agreements shall explicitly be required to comply with the terms and conditions of the Code.

7.1.3 TREATMENT OF THIRD PARTY CONTRACTS

All obligations and rights under the Code shall remain with the Generator when engaging Third Party services. In instances where Third Party contractors are granted access to a Generator's Facility by a Generator, the responsibility for ensuring that the rules and regulations under this Code are adhered to remain with the Generator.

7.2 MONITORING AND REVIEW OF THE GENERATION CODE

7.2.1 THE ROLE OF THE OUR

The role of the OUR with respect to this code shall be to promulgate, apply and enforce its provisions. The rights and obligations under this Code and the application thereof cannot be changed or otherwise altered without the written approval of the OUR.

Upon receipt of a revised version of the Code from the Panel, the OUR shall submit comments to the Panel within 30 days and the final ratification process of the Code should take no more than 3 months.

7.2.2 THE GENERATION CODE REVIEW PANEL

The OUR, in consultation with relevant stakeholders, shall establish and keep current a Generation Code Review Panel (the 'Panel'), which shall be a standing body charged with keeping the Code and its working under review. The Panel shall report to the OUR on its dealings and, as appropriate, recommend amendments to the Code for the OUR's approval.

The Panel shall start the Code review at June 1 of each year and has up to 3 months to conduct the review before making its submission to the OUR.

Duties

As part of its mandate, the Panel shall have following duties:

- i) Review of the Code prior to the beginning of each calendar year and otherwise as necessary to ensure that all operational procedures and requirements governed by the Code remain up to date.
- ii) Review all proposals for amendments to the Code which the Grid Operator, the Generators or the OUR from time to time may wish to submit to the Panel for consideration;
- iii) Following any unforeseen circumstances referred to it by the Grid Operator and/or other relevant stakeholders in accordance with Sub-section 7.3 consider; whether the actions taken by the Grid Operator was justified; and what changes, if any, are necessary to the Code;
- iv) Present recommendations to the OUR as to amendments to the Code that the Panel considers warranted and the reason for such changes.

Composition

The Panel shall consist of the following composition:

- i) One Member representing Grid Operator's System Control Center;
- ii) One Member representing Grid Operator's Transmission System;
- iii) One Member representing JPS owned Generating Units;
- iv) One Member representing JPS IPP Administrations Unit
- v) One Member for each IPP with a rated Capacity 15 MW and above; and
- vi) One Member representing all IPP's or Co-generators with a rated Capacity less than 15MW. The representative for the group of Generators with rated capacity less than 15 MW ('Small Generating Facilities') must be formally nominated or demonstrate endorsement by the Sub-Group.

The Sub-Group of Generators with capacity less than 15 MW should have their own meetings or communication forum where they compile their issues for the representative of the Sub-Group to take to the main Generation Code Review Panel. If the members of the Sub-Group of Generators are dissatisfied with the performance of their nominated representative at the main Generation Code Review Panel, they can then copy their list of issues and positions to the chair of the main Generation Code Review Panel and then the OUR for redress.

Each IPP interconnected to the System Grid shall have a licence to supply electricity generating capacity and a PPA with the Grid Operator.

The entities eligible for membership on the Generation Code Review Panel shall be responsible for providing the names of the persons (Primary and Alternate) who shall represent its membership to the Panel. These names shall be provided to the OUR one month prior to the start of each annual review period starting January of each calendar year. The person named as Alternate is required to remain fully abreast of all relevant discussions and proceedings to ensure a seamless transition from Primary to Alternate if required.

Each entity eligible for membership on the Panel reserves the right to change its named representative to the Panel at any time.

The Panel shall appoint its Chairperson from its membership by majority vote. The tenure of the chairperson shall be one year, unless summarily removed by majority vote of the panel. In addition to the annual review, the Chairperson shall preside over quarterly meetings of the Panel, to review and address issues relevant to the Code that may arise from time to time.

The OUR shall set up and maintain a Generation Code Secretariat responsible for providing routine administrative support to the Generation Code Review Panel. Administrative responsibilities of the Secretariat include, inter alia, compiling a list of the Code issues received throughout the year, arranging meetings of the Panel, developing and managing a budget (provided by the OUR); taking minutes of meetings and also liaising with the Chairperson of the Panel; disseminating information generated by the Panel among other things. The Generation Code Secretariat shall work in tandem with the Chairperson on matters relating to the Code.

Rules and Procedures for Conduct of Business

The Panel shall establish and comply at all times with its own rules and procedures governing the conduct of its business which the OUR shall approve. The Panel shall examine the Code from a technical perspective and make recommendations to the OUR.

If the Panel on any matter presented before it is unable to reach unanimous agreement or consensus, a maximum of three positions shall be presented and voted on by the Panel and the details of every vote (the persons who voted for each position not just the total number of votes per position) shall be presented to the OUR for determination of the matter. Any such referral to the OUR shall set out the cause of disagreement and the views held by the respective members. The quorum for the Generation Code Review Panel meetings shall be seventy percent (70%) of the Panel composition.

7.2.3 REVISIONS OF THE CODE

The Panel from time to time shall prepare and recommend amended versions of the Code to the OUR for its consideration and approval. The OUR shall notify the Panel of the accepted amendments as well as those that still remain in issue, in a separate document. If the OUR rejects the position of a Panel amendment and wishes to propose alternate text, this text should also be presented to the Panel for its consideration prior to finalizing the Code. The OUR shall inform, in writing, all Generators subject to this Code that an amended version has been issued.

7.3 UNFORESEEN CIRCUMSTANCES AND SYSTEM EMERGENCIES

7.3.1 UNFORESEEN CIRCUMSTANCES

If circumstances arise which are not addressed by the Code, the Grid Operator, shall, to the extent practicable in the circumstances, consult promptly and in good faith with all affected Parties in an effort to reach agreement as to the required course of action. If such agreement cannot be reached in the time available the Grid Operator shall refer the matter to the OUR with a view to determining the course of action to be taken.

Whenever the OUR makes a determination, it shall do so having regard, wherever possible, to the views expressed by the Generators and the Grid Operator, in any event, to what is reasonable in the circumstances. Each Generator and the Grid Operator shall comply with the instructions given to it by the OUR as a consequence of such a determination, provided that the instructions are consistent with the technical parameters set out in the Code, the respective Licences and PPAs. The OUR shall promptly refer all unforeseen circumstances and any determinations to the Generation Code Review Panel for consideration.

7.3.2 FORCE MAJEURE

All Parties should note that the provisions of the Code may be suspended in whole, or in part, pursuant to any directions or orders given by the OUR in situations of Force Majeure.

7.4 NON-COMPLIANCE

If a Generator finds that it is, or will be, unable to comply with any provision of the Code it shall, without delay, report such non-compliance to the Grid Operator and, subject to Sub-section 7.5 make all reasonable efforts as are required to remedy the cause of non-compliance as soon as reasonably practicable.

The Grid Operator and all Generators shall report all material incidents of non-compliance to the OUR.

If the Grid Operator finds that it is, or will be, unable to comply with any provision of the Code it shall, without delay, report such non-compliance to the OUR and, subject to Sub-section 7.5 make all reasonable efforts as are required to remedy the cause of non-compliance as soon as reasonably practicable.

7.5 DEROGATION

7.5.1 NORMAL PROCEDURE WHEN NON-COMPLIANCE IS

- i) in respect of apparatus connected to the System Grid and is caused solely or mainly as a result of amendments to the Code issued pursuant to Sub-section 7.2 ;
or
- ii) in respect of apparatus for which approval to connect is being sought; and the Generator judges that it would be unreasonable to require it to remedy the non-compliance or that it should be granted an extended period to remedy the non-compliance, the Generator shall promptly submit a request, in writing, to the Grid Operator and copied to the OUR regarding any derogation from the affected provisions in the Code; or
- iii) in respect of the System Grid and is caused solely or mainly as a result of amendments to the Code issued pursuant to Sub-section 7.2

Request for Derogation

A request for derogation from any provision in the Code shall contain the following information:

- i) The clause against which the present or predicted non-compliance is identified;
- ii) The reason for non-compliance with the provision;
- iii) Identification of the apparatus in respect of which a derogation is being sought;
- iv) Whether the derogation sought is for a delay in achieving compliance or permanent; and

If a delay in achieving compliance is being sought, the date by which the non-compliance will be remedied.

Basis for Granting or Refusing Derogation

On receipt of a request for derogation pursuant to this clause, the Grid Operator shall consider whether such derogation can be granted without having a material adverse effect on the security, stability or economics of System operation. The Grid Operator shall submit its recommendation on the request for such derogation to the OUR for review and determination. The submission shall set out the reason(s) for the recommendation and the original request.

On receipt of a request for a derogation pursuant to this clause from the Grid Operator with respect to the System Grid, the OUR shall consider whether such derogation can be

granted without having a material adverse effect on the security, stability or economics of System operation. The submission shall set out the reason(s) for the request and the potential impact on the system if derogation is granted.

Once a decision has been made and approved by the OUR, the Parties involved shall be promptly informed of the decision and, in the event that the request is refused, the reason(s) for such refusal shall be provided.

7.5.2 DEROGATION FOR EXISTING APPARATUS NOT IN COMPLIANCE

Not all apparatus in use as at the date of promulgation of this Code will be able to meet the Technical Standards defined by this Code. In some cases, it may not be economical or technically necessary to upgrade such existing apparatus to the required Technical Standards.

If the OUR stipulates that measures are essential for compliance with any version of the Code which may be different from specific PPA conditions and/or Licence provisions, then the OUR shall determine the appropriate mechanism for dealing with contingencies associated with compliance including associated costs if any.

7.6 DISPUTE RESOLUTION

7.6.1 MUTUAL DISCUSSION

If a dispute or difference of any kind whatsoever (the 'Dispute') between the Grid Operator and any Generator in connection with, or arising out of, any clause in this Code, either Party may issue to the other Party a written notice (the 'Dispute Notice') outlining the matter in dispute. Following issue of a Dispute Notice both Parties shall discuss in good faith and attempt to settle the dispute between them.

7.6.2 REFERRAL AND DETERMINATION BY THE OUR

If the Dispute cannot be settled within 30 days after issue of the Dispute Notice, either Party shall have the right to refer the Dispute to the OUR for resolution.

- i) The request for referral shall be made in writing to the OUR and a dated copy of the original Dispute Notice between the Parties shall be attached.
- ii) Upon receipt of a request for referral, the OUR shall write to both Parties acknowledging that the Dispute has been referred to the OUR for determination.

- iii) Following receipt of OUR acknowledgment, each Party shall have five (5) working days to submit their reason (s) as to the cause of the Dispute in writing to the OUR.
- iv) No later than ten (10) working days after the OUR has received each Party's reason (s) in writing, the OUR shall write to each Party setting out how the OUR intends to resolve the Dispute and indicate a date by which a determination may be expected.

Notwithstanding the above, all Generators reserve the right to seek resolution of Disputes under its PPA or Licence.

7.7 NOTICES

Notices and Communique relating to the Code should be directed to the following contact details:

Entity	Contact	Address	Phone	Fax	Email
OUR	Courtney Francis Engineer	36 Trafalgar Road Kingston 10	968-6053	929-3645	cfrancis@our.org.jm
JPS	Head, Govt. & Regulatory Affairs Sam Davis	Jamaica Public Service Co. Ltd. 6 Knutsford Boulevard Kingston 5	935-3500	511-2000	SDavis@jpsco.com
JEP	General Manager: Wayne McKenzie	10-16 Grenada Way Kingston 5	920-1746	920-1750	wmckenzie@jamenergy.com
JPPC	General Manager: Jose Arenivar	100 Windward Road Kingston 2	938-3983 -4	938-3982	Jose.arenivar@jppc1.com
Jamalco	Mark Peterkin	Halse Hall May Pen Clarendon	986-2561-4	986-2804	mark.peterkin@alcoa.com
Wigton Windfarm	General Manager: Earl Barrett	36 Trafalgar Road Kingston 10	960-3994	960-3108	earl.barrett@wwfja.com
Jamaica Broilers	CEO: Christopher Levy	McCook's Pen St. Catherine	943-4376		clevy@jabgl.com
West Kingston Power Partners	General Manager: Wayne McKenzie	10-16 Grenada Way Kingston 5	920-1746	920-1750	wmckenzie@jamenergy.com
Small Generators Nominee (<15 MW)					

SCHEDULES

TO

GENERATION CODE

SCHEDULE A: TERMS AND DEFINITIONS

TERM	DEFINITION
Allowable Error	The error associated with metering equipment described in this Code which shall not exceed $\pm 0.5\%$ of full scale reading.
Backup Metering System	The meters and metering devices owned by the Generator and used to measure the delivery and receipt of Net Energy Output, Dependable Capacity and other parameters pursuant to Section 2 of this Code.
Base load Unit	A Generating Unit designated to operate for more than 8000 hour per annum and do not go through cycles of economic shut down.
Black Start	The procedure necessary to recover from a total or partial shutdown
Black Start Capability	The ability to restart the generating facility in the absence of incoming power from the grid.
Black Start Generating Unit	A Generating Unit with Black Start Capability
Code	This Generation Code and the Schedules hereto.
Cogeneration Facility	The facility which simultaneously provides electrical and thermal energy from a singular fuel source for a customer's process requirements as well as electrical output to System Grid.
Connection Condition	This term shall have the meaning assigned thereto in Section 1.
Corporate Area	That portion of the System Grid that serves Kingston and St. Andrew.
Cycling Units	A Generating Unit required to operate less than 8000 hours per annum and designed to withstand cycle of economic shut down and start up.
Day	The 24 hour period beginning and ending at 00:00 hours Eastern Standard Time.
Dead Bus Control	Connecting a generating facility to a de-energised grid and having it perform frequency and voltage control.
Demand	The rate at which electric energy is being used.
Demand Interval	The period over which the Demand is integrated
Dependable Capacity	The maximum Capacity modified for ambient limitations which a Generating Unit, or item of electrical equipment can sustain over a specified period of time.
Dispatch Instructions	The instructions issued by the Grid Operator from System Control Center to the Generator to schedule and control its generation in order to increase or decrease the electricity delivered to the System Grid.

Dispatchable Generating Unit	Generating Units whose required level of output at any instant of time is determined and regulated by the System Control Engineer.
Dispute	Any controversy or difference between the Grid Operator and a Generator in connection with, or arising out of, any clause in the Generation Code.
Dispute Notice	A written notice issued by either Party to a Dispute outlining the matter in Dispute.
Distribution System	That portion of an electric system which transfers electric energy from the bulk electric system to the customers.
Embedded Generating Facility	A Generating Facility that is connected to a Distribution System that has no connection to the Transmission System.
Economic Dispatching Technique	The approved method used to rank Generating Units by their economic merit and to determine at which level they should be dispatched to minimize total variable operating cost subject to Generating Units operating limits and system constraints.
EMS	Energy Management System
Equal Incremental Cost Principle	The Equal Incremental Cost Principle relates to the economic dispatch of power generation where each Generating Unit on line, should operate at the same System wide point of Incremental Cost to serve a given load. Refer to Sub-section 3.6.
Force Majeure	Causes beyond the reasonable control of and without the fault or negligence of the Party claiming Force Majeure. It shall include failure or interruption of the delivery of electric power due to causes beyond that Party's control, including acts of God, wars, sabotage, riots, hurricanes and other actions of the elements, civil disturbances and strikes.
Forced Outage	An interruption of a Generating Unit's capability to generate power that is not the result of (i) a request by the Grid Operator (ii) a Scheduled Outage or a Maintenance Outage; or (iii) an event or occurrence of Force Majeure.
Fuel Supply Plan	The Generator's plan for providing fuel to ensure its operation in accordance with the terms and provisions of this Code or any contracted Power Purchase Agreement. The Fuel Supply Plan shall include, but not be limited to, the Generator's proposed fuel specification, fuel supply and transportation arrangements, and the Generator's plans to obtain fuel on the most economic basis at any given time.
Full Load Point	The declared maximum capacity pursuant to the most recent Dependable Capacity Test (DCT) consistent with respective PPA conditions.
Full Load Rejection	The loss of demand that is equivalent to the full load rating of a generating unit that is separated from the Grid at the time when the unit is operating at full load.

Generator	Owner and/or operator of an electricity generating facility, supplying power to the Grid Operator via the System Grid, including JPS.
Generating Facility	Any facility whether privately or JPS owned containing one or more Generating Units and associate infrastructure producing and delivering electrical energy to the System Grid
Generating Unit	Any electric power generating plant or apparatus, whether privately or JPS owned, delivering electrical energy to the System Grid.
Generation Code	The guiding principles, operating procedures and Technical Standards governing operation of the Jamaican Power System Grid and all interconnected Generating Facilities, as from time to time revised with the approval of the OUR.
Generation Code Review Panel	A Panel responsible for keeping this Code and its working under review in accordance with Clause 7.2.2.
Grid Operator	Is responsible for prudent and efficient management of the Jamaican electricity System and in that capacity, for dealing with all Generators in a consistent and non-discriminatory manner.
Heat Rate	The measure of a Generating Unit's thermal efficiency, expressed as the number of thermal energy units to produce one kWh of electrical energy.
Heat Rate Curve	A plot of Heat Rate changes between minimum and maximum output levels of a Generating Unit.
Heat Rate Test	A test of a Generating Unit's thermal efficiency carried out in accordance with Clause 3.2.1 (ii).
High Voltage	On the System Grid, this is either 69 kV or 138kV
HV	High Voltage
Incremental Cost	The meaning ascribed thereto in Sub-section 3.6.
Independent Engineer	The independent licensed professional Engineer jointly selected by the Parties who, among other things, shall receive copies of all test results performed pursuant to Section 6 on the Generating Facility for the purpose of certifying in writing that the Facility can be satisfactorily commissioned. The fees charged by the Independent Engineer shall be borne by the Generator
Interconnection Agreement	An agreement which outlines the specific requirements for the interconnection of Generating Units to the System Grid as arrived at between a Generator and the Grid Operator. This Agreement is sometimes contained in PPAs as a Schedule
Interconnection Point	The physical point(s) where the Generator and the System Grid are connected as specified in Sub-section 1.1.
Independent Power Producer	Any private Generator other than JPS selling power to the System Grid.

IPP	Independent Power Producer
JPS	Jamaica Public Service Company Limited
kW	Kilowatts.
kWh	Kilowatt hours.
Load	Demand in watts or multiples thereof.
Low Voltage	On the System Grid voltage of 24 kV or less
Load Shedding	The automatic or manual disconnection or interruption of the electrical supply to a customer Load by the utility, usually to mitigate the effects of generating Capacity deficiencies or transmission limitations.
LV	Low Voltage.
Maintenance Outage	An interruption or reduction of the Generating Unit capability that: i. is not a Scheduled Outage; or ii. has been scheduled and allowed by the Grid Operator in accordance with Section 5; and iii. is for the purpose of performing work on specific components, which work could be postponed by at least six (6) Days but not be postponed until the Scheduled Outage.
Merit Order	The ranking of Generating Units in the order of Variable Operating Cost. It is used as the basis for committing Generating Units into operation. The Generating Unit with the least Variable Operating Costs is ranked first; the Generating Unit with the next lowest variable operating costs is ranked second and so forth.
Metering System	All meters and metering devices (including the Primary and Backup Metering Systems) used to measure the delivery and receipt of Net Energy Output, Dependable Capacity and other parameters pursuant to Section 2 of this Code.
Month	A calendar Month according to the Gregorian calendar beginning at 00:00 hours Eastern Standard Time on the last day of the preceding Month and ending at 00:00 hours Eastern Standard Time on the last day of that Month.
MVA	Megavolts Amperes
MVAR	Megavolt Amperes reactive.
MW	Megawatts.
MWh	Megawatt hours.
Net Energy Output	Net energy delivered by the Generator for sale to the Grid Operator at the Interconnection Point in accordance with a valid Dispatch Instruction.
Nominal Operating Voltage	Voltage that is required electrically at any point of the System Grid
Non-Dispatchable Generating Units	Generating Units will be classed as Non-Dispatchable when it is not practical to control or dictate the required level of output

	of these units to the System Grid on an ongoing basis.
Non-Spinning Reserve	That reserve in MW not connected to the System but capable of serving Demand within a specified time.
Operating Reserve	Generating capability in MW above firm System Demand available to provide for regulation, load forecasting error, equipment forced and scheduled outage. It consists of Spinning and Non Spinning Reserve.
Operations Log	A record of significant operating events, plans, requests and instructions.
OUR	Office of Utilities Regulation. The Regulatory Authority for Jamaica's utility sector
Partial Load Rejection	The partial or complete loss of power consumers without the separation of a generating unit from the grid with the generating unit initially operating at full load
Parties	System Grid Operator and Generator
Party	System Grid Operator or Generator
Peak Hours	The hours between 5:00 pm and 9:00 pm Eastern Standard Time every day of the week.
Power Factor (pf)	Ratio of Megawatt output to corresponding MVA.
Power Purchase Agreement (PPA)	An agreement between a Generator and the Grid Operator which defines the technical, commercial and legal terms of the arrangements related to the power interchange between the entities.
Primary Metering System	All meters and metering devices (financed by the Generator but owned by the Grid Operator) used to measure the delivery and receipt of Net Energy Output, Dependable Capacity and other parameters pursuant to Section 2 of this Code.
Prudent Utility Practice	The practices generally followed by the electric utility industry in respect to the design, construction, operation, and maintenance of electric generating, transmission, and distribution facilities, including, but not limited to, the engineering, operating, and safety practices generally followed by such utility industries.
Qualifying Entity or QE	a residential or non-residential entity which is the legal owner of the QF
Qualifying Facility or QF	an approved intermittent renewable energy system with nameplate capacity less than or equal to 100 kW
Rapid Start	The ability for a generating set to be started and synchronized in less than 10 minutes after an instruction is given to do so by the grid operator.
Rated Capacity	A measure of the ability to generate electric power continuously usually expressed in Megawatts or kilo Watts.
Reactive Power	The Wattless component of the product of voltage and current, which the Generating Unit shall provide to or absorb from the System Grid and which is measured in MVAR.

Rural Area	Area of Jamaica that does not fall within the Corporate Area
Scheduled Outage	A planned interruption of the Generator's generating capability that: i. is not a Maintenance Outage; ii. has been scheduled and allowed by the Grid Operator in accordance with Section 5; and iii. is for inspection, testing, preventive maintenance, corrective maintenance or improvement.
Spinning Reserve	Unloaded generating capacity in MW which is synchronized and ready to serve additional Demand.
Sequence of Events	Record of power system activities with respect to time.
Substation	Grouping of equipment inclusive of transformers, circuit breakers, switches and protective devices used to facilitate among other things the transformation of voltages and switching operations. A combination of generation, transmission, and distribution components within a specially defined area.
System Control Center	The System Control Center located in Kingston, Jamaica, or such other control center designated by the Grid Operator from time to time (but not more than one at any time) from which the Grid Operator shall issue Dispatch instructions to the Generators.
System Control Engineer	Person appointed by the Grid Operator and on duty at System Control Center with responsibility for controlling the generation, transmission and distribution of electrical energy.
System Emergency	A condition or situation that, materially and adversely, or is likely to materially and adversely; (i) affect the ability of the Grid Operator to maintain safe, adequate and continuous electrical service to its customers, or (ii) endanger the security of person, plant or equipment.
System Grid	The Interconnection Facilities and any other transmission or distribution facilities on the Grid Operator' side of the Interconnection Point(s) through which the electrical energy output from the Generating Unit(s) will be distributed by the Grid Operator to users of electricity.
Synchronization	The controlled interconnection of System facilities to operate in phase at the same frequency and voltage.
Technical Standards	All standards as outlined in Clause 1.2.1 or any other acceptable benchmark or method as defined or in use by the Grid Operator.
Ten Minutes Reserve	An additional amount of operating reserve sufficient to reduce generation deficiency within ten minutes following the loss of generating capacity;
Transmission System	That section of the System Grid between the Generator interconnection point and the HV side of the Distribution Substation. This System is operated at 69 kV and 138 kV.

Unit Controller	Person designated by the Generator to oversee the operation of any of the Generating Units and to liaise with System Control Engineer in this process.
Unit Commitment Schedule	The sequence of startup and shutdown time of thermal Generating Units which minimizes the total production cost including startup and shutdown costs over a period of at least 24 hours or up to a week, given the load forecast, and taking into account the Maintenance Schedule, generation reserve requirement and System security.
Variable Operating Cost	Costs that vary with production of electricity.
VOM	Variable Operation and Maintenance cost
Week	A period of seven (7) consecutive Days beginning at 00:00 hours Eastern Standard Time falling between a Saturday and a Sunday.
Year	Each twelve (12) Month period commencing on 00:00 hours Eastern Standard Time on December 31 and ending on 00:00 hours Eastern Standard Time the following December 31 during the term of this Code.

SCHEDULE B: REQUIRED COMMUNICATION EQUIPMENT

The Communication Systems used for System Operations are in two basic forms –VHF Radio for general operational communications (including mobile units), and a point-to-point telephone system for Substations and Generating Stations operation. For switching operations, the primary form of communication is radio while the secondary communication is telephone. For all other operations, telephone is the primary form of communication and radio is the secondary form. Proper use of these facilities is described in detail in the Grid Operator’s Policies and Procedures Manual for System Operation. However the following principles are especially noteworthy:

- The VHF radio system should be operated in accordance with stipulated protocols.
- Transmitter/receiver sets are located at all District offices, Power Stations, major Substations and in the Generator’s Operating vehicles
- Communication equipment should be properly maintained and any malfunction of such equipment be reported to System control promptly
- In the event of loss of communication (including Public Telephone facilities) between a generating station and System Control, the Generator’s management must assume full direction and control of the Station. All actions taken and their corresponding times must be logged and reported to system control as soon as communication is restored. In any such event the first priority is safety and then system integrity. The Generator shall not change the operations and shall maintain the last dispatch while maintaining safety.

SUPERVISORY CONTROL AND DATA ACQUISITION

The Supervisory Control And Data Acquisition (SCADA) System is currently used to monitor and record status and analogue values at relevant data collection points throughout the system. Required points for monitoring include circuit breakers, switches, potential transformers and current transformers.

The SCADA system performs constant scanning of all data points and logs a status update every two seconds, unless a significant non-transient change occurs that results in a monitored value exceeding its predefined limits, in which case the resolution of the data recorded is in milliseconds. It is therefore necessary that the monitoring/control devices

installed at the Generating Station be capable of sub second response to a degree equal to or better than that of the System's SCADA equipment.

REQUIRED COMMUNICATION EQUIPMENT

Each Generator shall install and maintain at each Generating Station at its sole cost and expense:

- i) Compatible Remote Terminal Units ("RTUs") to allow interfacing of SCADA status and analog signals from the generating station to the centralized SCADA system at system control, specifically transmitting:
 - a) Three phase values of watts, vars, voltage, and current as well as busbar frequency
 - b) Status (open, closed) of the relevant circuit breakers
- ii) Adequate Power Line Carrier Channels to System Control Centre for the purpose of tele-metering, protection and telecommunications.
- iii) An extension of System Control Centre PBX System in the Generating Units control room to facilitate (hotline) voice communication between the Generator control room and System Control Centre.
- iv) Telecommunications facilities such as Internet and landline telephones in the Generating Units control room to transmit and receive telecopies/facsimiles and electronic mail to and from System Control Centre respectively.
- v) UHF and VHF radio equipment to permit voice communication between the Generating Unit control room and System Control Centre.
- vi) Microwave equipment to transmit data to System Control Centre.
- vii) A synchronized digital GPS Clock to allow time stamping of all analog and status communications especially those logged by the Sequence of Events recorder.

SCHEDULE C: LOAD SHEDDING SCHEME

CURRENT SETTING OF UNDER-FREQUENCY RELAYS

The Under-Frequency Relay set points as at the date of this document are as follows:

Stage	Under-Frequency Relay Setting
0	49.35
1	49.2
2	48.9
3	48.5
4	48.1

SCHEDULE D: RESERVE MARGIN POLICY

SPINNING RESERVE POLICY:

SYSTEM OPERATION POLICIES AND PROCEDURES

CLIENT: JAMAICA PUBLIC SERVICE COMPANY LIMITED

Ref. No. 8 Page: 1 of 1

SUBJECT: OPERATING SPINNING RESERVE POLICY

Effective Date: _____

			Responsibility	References
The following details the company's spinning reserve policy. A minimum spinning reserve capacity of 30 MW should be planned to meet the daily system demand. Consistent with the above policy, the following measures should be adopted: - The Old Harbour units (OH2, OH3, OH4) and Hunts Bay B6 steam unit are to be limited to a maximum of 85% of their Maximum Continuous Rating (MCR). The difference between the reserve allocated by the above restrictions and the stipulated 30 MW operating spinning reserve is to be allocated across the system by means of an economic optimization process. - Under normal circumstances a gas turbine should not be started with the spinning reserve above 30 MW. However, if the margin should fall below 30 MW, a gas turbine can be used to assist in maintaining a margin of spare plant. - Gas Turbines should be used for quick load restoration following operation of under frequency relays. (At least two of the aeroderivative GTs (GTs 6, 7, 8, 9, 11) should be on remote standby for this purpose, unless they are required to meet the demand. - No single generator should be allowed to carry more than 27.7% of the total demand. This is in keeping with the system overload protection of 33%. Provisions for this is made in the ELD programme.			Operation Planning Engineer System Control Engineer System Control Engineer System Control Engineer/Bogus Operations Manager Operations Planning Engineer/System Control Engineer	Section 7.2
Approved By <i>Ricardo Case</i>	Status Active	First Effective Dec 2006	Supersedes Apr 03	Reviewed By Ricardo Case


4/09/05

SCHEDULE E: EXISTING GENERATING SYSTEM

Unit	Capacity (MW)	Technology	Fuel Type	Location	Remarks
RF#1	20.0	Slow Speed Diesel	HFO	Rockfort	
RF#2	20.0	Slow Speed Diesel	HFO	Rockfort	
OH#1	30.0	Steam	HFO	Old Harbour	Out of service
OH#2	60.0	Steam	HFO	Old Harbour	
OH#3	65.0	Steam	HFO	Old Harbour	
OH#4	68.5	Steam	HFO	Old Harbour	
HB#B6	68.5	Steam	HFO	Hunt's Bay	
GT#5	21.5	ADO Fired Gas Turbine	ADO	Hunt's Bay	
GT#10	32.5	ADO Fired Gas Turbine	ADO	Hunt's Bay	
GT#3	21.5	ADO Fired Gas Turbine	ADO	Bogue	
GT#6	14.0	ADO Fired Gas Turbine	ADO	Bogue	
GT#7	14.0	ADO Fired Gas Turbine	ADO	Bogue	
GT#8	14.0	ADO Fired Gas Turbine	ADO	Bogue	
GT#9	20.0	ADO Fired Gas Turbine	ADO	Bogue	
GT#11	20.0	ADO Fired Gas Turbine	ADO	Bogue	
Bogue Combined Cycle	114.0	ADO-CCGT	ADO	Bogue	
Maggotty	6.0	Run of River Hydro		Maggotty	
Lower White River	4.75	Run of River Hydro		White River	
Upper White River	3.19	Run of River Hydro		White River	
Roaring River	4.05	Run of River Hydro		Roaring River	
Rio Bueno "A"	2.5	Run of River Hydro		Rio Bueno	
Rio Bueno "B"	1.1	Run of River Hydro		Rio Bueno	
Constant Spring Hydro	0.75	Run of River Hydro		Constant Spring	
JPPC - IPP	60.0	Slow Speed Diesel	HFO	Rockfort	
JEP - IPP	124.2	Medium Speed Diesel	HFO	Old Harbour	
WKPP - IPP	65.5	Medium Speed Diesel	HFO	Hunts Bay	
Wigton Wind Farm I	20.7	Wind Turbines		Wigton	Energy only
Wigton Wind Farm II	18.0	Wind Turbines		Wigton	Energy only
Munro College	0.25	Wind Turbine		Munro	
JPS Munro Wind	3.0	Wind Turbines		Munro	
Jamaica Broilers	as-available	Slow Speed Diesel	HFO	Spring Village	
JAMALCO	11.0	Steam - Cogen	HFO	May Pen	
JAMALCO	as-available	Alternative		St Jago, Clarendon	

ADO Automotive Diesel Oil
 GT Gas Turbine
 HB Hunts Bay
 HFO Heavy Fuel Oil
 IPP Independent Power Producer
 JEP Jamaica Energy Partners
 JPPC Jamaica Private Power Company
 OH Old Harbour
 RF Rockfort
 WKPP West Kingston Power Partners

LAYOUT OF JAMAICA'S GENERATION AND TRANSMISSION SYSTEMS



SCHEDULE F: GRID OPERATOR INTERCONNECTION CRITERIA

GENERATING UNIT(S) CONNECTED TO THE JAMAICAN TRANSMISSION SYSTEM

	Category	System Operations Criteria/Parameters	Plant/Generator Design Criteria	Comments	Generation/ Transmission Code Ref.
Transmission System Security	Interconnection Voltage	Generating Unit(s) at rated capacity >10MW shall be connected to the Transmission system at 69kV or 138kV.		The Grid Operator on the basis of System Security, Stability and Safety shall determine the interconnection voltage.	GC 1.1.2
	Reliability of Generating Unit(s) Grid Connection Points	All substations shall have the capability to disconnect or separate, from the System Grid, any transmission line and/or generating unit that is interconnected to the substation.	Substations (including Generation substations) with more than three (3) transmission lines or generating units shall be of a "breaker and a half configuration".		GC 1.1.3
	Loss of Generation	For the loss of one transmission element there shall be no loss of generation > 60MW.	The loss of any single transmission element connecting a generating unit(s) shall not result in a loss of generation greater than 60MW. Therefore generation greater than 60MW shall be designed on the N-1 principle.		GC 1.1.1

	Category	Operations Mode	Unit	System Operations Criteria/Parameters	Plant/Generator Design Criteria	Comments	Code Ref.
Plant Performance	Frequency	Nominal	Hz	50	Generating plant and auxiliary apparatus shall be designed to operate at this nominal frequency (continuous operation).	Intermittent and/or renewable type generating plant shall maintain active power output as per the turbine/generator power curve characteristics.	GC – Sect. 1.2.2
		Normal Operating Band	Hz	49.5 – 50.5	Maintain constant Active Power output at any load point. Generating plant and auxiliary apparatus shall be designed to operate in this range.		GC – Sect. 1.2.2
		Abnormal	Hz	48.5 – 49.5 50.5 – 52.5	Maintain constant Active Power output at any load point. Plant and Apparatus shall be designed to operate in this range (continuous operation)	Intermittent and/or renewable type generating plant shall define the limitations of generating unit(s) to meet these criteria for review and approval by the Grid Operator.	GC – Sect. 1.2.2
			Hz	48.0 – 48.5	Maintain, for at least one (1) second, Active Power within 95% and 100% of output loading levels before abnormal frequencies occurred. Generating plant and auxiliary apparatus shall be designed to operate in this range.		
			Hz	<48.0	Generator trip settings shall be as agreed with the Grid Operator.		
	Voltage	Nominal	KV	69kV or 138kV	Reactive power output shall be fully available under steady state conditions.		GC – Sect. 1.3
		Normal Operating Band (± nominal kV)	%	± 5%	Reactive power output shall be fully available under steady state conditions (continuous operation). The Generating Unit shall not be affected by voltage changes in this operating band.	Generating plant requiring reactive power support (e.g. induction generators) shall provide their full reactive power compensation within the specified voltage operating bands (normal and abnormal)	GC – Sect. 1.3
		Abnormal	%	± 10%	Reactive power output shall be fully available under steady state conditions		

	Category	Operations Mode	Unit	System Operations Criteria/Parameters	Plant/Generator Design Criteria	Comments	Code Ref.
					(continuous operation) as per the capability curve of the plant. The Unit(s) and auxiliaries shall not lose synchronism or trip by voltage changes in this operating band.		
	Voltage Dips (Fault Ride Through Capability)	Abnormal	% of nominal bus kV	10% to 90%	VOLTAGE DIPS OF DURATION $\leq$ 120ms The generating unit(s) shall remain stable and connected to the system without tripping or losing synchronism for transmission voltage dips less than or equal to 120ms in duration.	See FIGURE A for Low Voltage Ride Through (LVRT) Curve.	
					VOLTAGE DIPS OF DURATION $>$ 120ms For transmission voltage dips occurring due to system disturbances greater than 120ms (6 cycles) in duration the generating unit(s) shall: During Voltage Dip 1. Remain transiently stable and connected to the system for at least 1 second without tripping/losing synchronism. 2. Provide Active Power output during voltage dips at least in proportion to the retained balanced voltage at the Interconnection Point. Immediately After Voltage Dip 3. Restore Active Power output at the Interconnection Point to 90% of nominal levels (available immediately before the occurrence of the dip) within 1 second of restoration of steady state voltage conditions. That is, within the normal voltage operating band of 69kV $\pm$ 5%		

	Category	Operations Mode	Unit	System Operations Criteria/ Parameters	Plant/Generator Design Criteria	Comments	Code Ref.
	Negative Phase - Sequence Component of phase voltage	Normal	%	<1%	Sustained operation at any load (continuous operation)		
	(Unbalance loading withstand capability)	abnormal	%	≤2%	Sustained operation at any load (continuous operation)		
	Negative Phase - Sequence Component of phase voltage cont'd (Unbalance loading withstand capability)	faults			Generating unit shall withstand, without tripping, the negative phase sequence loading incurred by <u>clearance</u> of a close-up phase-to-phase fault by system back-up protection on the Transmission System.	The Grid Operator shall provide relay settings upon request.	
	Plant Output	Normal	MW	Rated Generating Unit output shall be provided in the Interconnection or Power Purchase Agreement.	Supply rated Active Power (MW) at any point between limits 0.85 pf lagging and 0.95 pf leading at generator terminals. Reactive power output shall be fully variable between these limits.	Intermittent and/or renewable type generating plant shall maintain Active Power (MW) output as per the turbine/generator power curve characteristics.	
	Synchronisation	Normal			1. Synchronise and parallel/load transfer with grid without causing voltage fluctuation at Interconnection Point >±5% of voltage at Interconnection Point. 2. Synchronise to Grid within voltage ±5% of nominal and frequency 50±0.5Hz		
		Abnormal			Synchronise to Grid within voltage		

	Category	Operations Mode	Unit	System Operations Criteria/Parameters	Plant/Generator Design Criteria	Comments	Code Ref.
					±10% of nominal and frequency 50±0.5Hz		
Controls	Frequency Control	Normal			Each generating unit shall be capable of contributing to frequency control by continuous modulation of Active Power supplied to the Transmission system. The unit shall be fitted with a fast-acting speed governing system that shall have an overall speed droop characteristic of five (5) percent or less. The speed governor deadband shall be no greater than 0.1 Hz.	Applicable on a Case-by-Case basis for intermittent and/or renewable type generating plant. The droop setting shall be 5%.	
	Voltage Control	Normal			Each generating unit shall be capable of contributing to voltage control by continuous changes to the Reactive Power supplied to the Transmission system. <u>Automatic Voltage Regulator:</u> Deadband: not exceeding 0.5% Controls: Capability to control voltage continuously between 90% and upper limit of rated voltage of the generator from no load to full load. This range shall be covered linearly in approximately 1 minute.	Applicable on a Case-by-Case basis for intermittent and/or renewable type generating plant.	
	Excitation Control	Normal			Provide Constant Terminal voltage control of the synchronous generating unit without instability over the entire operating range of the unit	Applicable on a Case-by-Case basis for intermittent and/or renewable type generating plant.	
	Excitation Control (cont'd)	Normal			Excitation System (Large Signal Response): Voltage Response Time: less than 0.1		


	Category	Operations Mode	Unit	System Operations Criteria/Parameters	Plant/Generator Design Criteria	Comments	Code Ref.
					second for a voltage step change not to exceed 5% in terminal voltage Ceiling Voltage: minimum 160% of generator rated load field voltage.		
Protection	Generator Protection	Abnormal		Protect against: • Loss of Excitation • Under Excitation • Unbalanced Load Operation • Stator Phase Faults and Earth Faults • Reverse Power • Unit Over and Underfrequency • <u>Thermal Overload:</u> Stator Over Temperature, • Generator Overspeed • Restricted Earth Fault	Meet system protection requirements for all synchronous generating units.	Protection requirements for asynchronous generators to be reviewed and approved by the Grid Operator.	GC – Sect. 1.2.4
	Generating Unit Step Up Transformer (GSU)			Protect against: • Phase and earth faults (HV and LV) within the GSU zone • Transformer Tank Sudden pressure, • Differential Current • Backup protection if	Meet system protection requirements for all GSU.		

	Category	Operations Mode	Unit	System Operations Criteria/Parameters	Plant/Generator Design Criteria	Comments	Code Ref.
				failure of the plant local breaker to operate ○ The plant owner to provide breaker fail signal to Grid Operator switchyard			
	Interconnection Protection	Abnormal		Protect against: - Phase and Earth Faults (tie-lines, bus) - Failure of Grid Operator (JPS) remote protection to clear grid phase and earth faults (b/up protection) ○ Grid Operator (JPS) to provide breaker fail signal to generator owner switchyard - Failure of plant local breaker to operate (breaker fail)	Meet system protection requirements at Interconnection Point.	Protective system to be applied at the Interconnection Point shall be designed, coordinated and tested to achieve speed, sensitivity and selectivity in fault clearing. Relay types to be approved by the Grid Operator (JPS).	

	Category	Operations Mode	Unit	System Operations Criteria/ Parameters	Plant/Generator Design Criteria	Comments	Code Ref.
				protection) oThe generator owner to provide breaker fail signal to Grid Operator (JPS) switchyard			
Fault Clearing Times	Transmission bus (point of grid interconnection)	Maximum time	Milli-seconds (ms)	To be provided in Power Purchase Agreement (PPA) documents. In the absence of the requirement in PPA documents, fault clearing time (from fault inception to arc extinction) shall not be slower than: 69kV – 120ms 138kV – 100 ms	Meet or exceed system fault clearing times. The generating unit shall remain transiently stable and connected to the system without tripping for a close-up solid three phase fault or any unbalanced short circuit fault on the Transmission System up to the maximum total fault clearance time. During the period of the fault the generating unit shall generate maximum reactive current without exceeding the transient rating limit of the generating unit.		
Fault Levels	Transmission bus (point of grid interconnection)		Amps (A)	To be provided in Power Purchase Agreement (PPA) documents.	The maximum fault levels at the grid Interconnection Point shall be below 80% of the interrupting capacity of substation and plant apparatus determined using generator transient impedances.		

The owner of the Generating Unit(s) is required to submit to the Grid Operator all Generating Unit and Generating Unit Step-Up (GSU) transformer parameters upon completion of plant, apparatus and equipment designs.

FIGURE A: Low Voltage Ride-Through (LVRT) Curve



Generating Units must remain connected to the grid in the region above the Low Voltage Ride-Through (LVRT) curve.